

**GUJRANWALA ELECTRIC POWER COMPANY LTD.**

PH: 055-9200510

Fax No. \_\_\_\_\_ Dated: 07-09-2017

Memo No. 20716-24 O&M/Dist.

OFFICE OF THE  
CHIEF EXECUTIVE OFFICER  
GEPCO, GUJRANWALA  
Dated: 07-09-2017

**XEN SS&T DIVISION  
GEPCO GUJRAT**

Subject:- **SHUT DOWN**

Ref:- Your office No.4051 Dated: 06-09-2017.

Shut down on the following **11KV Feeders** is approved with the date & time mentioned against each, remarks of Chief Engineer (Operation) GEPCO Gujranwala to make ensure the proper publication in National daily newspapers & displa on web site of the Company (Electronic & Print Media).


S #	Name of G/S	Name of Equipment / T/Lines	Purpose	Date & Time Of Shutdowns		Area Affected
1	132KV G/S Phalia	132KV C.B PHL-1	For annual maintenance and testing of protection system.	9/9/17	0900 TO 1100	NIL
2	132KV G/S Phalia	132KV C.B PHL-2	For annual maintenance and testing of protection system.	9/9/17	1100 TO 1300	NIL
3	132KV G/S P.Rd Sialkot	132KV CB SPR-3 (Controlling P.Rd Sialkot – Lalapur T/Line)	For annual maintenance and testing of protection system.	11/9/17	0830 to 1100	NIL
4	132KV G/S P.Rd Sialkot	132KV CB SPR-4 (Controlling P.Rd Sialkot – Sahowala T/Line)	For annual maintenance and testing of protection system.	11/9/17	1100 to 1330	NIL
5	132KV G/S P.Rd Sialkot	132KV CB SPR-5 (Controlling P.Rd Sialkot – Cantt Sialkot T/Line)	For annual maintenance and testing of protection system.	11/9/17	1330 to 1600	NIL
6	132KV G/S City Sialkot	132KV CB STC-1	For annual maintenance and testing of protection system.	13/9/17	0900 TO 1100	NIL
7	132KV G/S City Sialkot	132KV CB STC-2	For annual maintenance and testing of protection system.	13/9/17	1100 TO 1300	NIL
8	132KV G/S Ratti	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	14/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
9	132KV G/S Ratti	132/11.5KV, 20/26MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	14/9/17	1200 To 1600	All O/G feeders of power T/F T-2 will be affected.
10	132KV G/S New Sialkot	132/11.5KV, 20/26MVA P.T/F T-4 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	15/9/17	0900 To 1300	All O/G feeders of power T/F T-4 will be affected.
11	132KV G/S P.Rd Sialkot	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	16/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
12	132KV G/S P.Rd Sialkot	132/11.5KV, 31.5/40MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	16/9/17	1200 To 1600	All O/G feeders of power T/F T-2 will be affected.
13	132KV G/S Old Power House (Sialkot)	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	18/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
14	132KV G/S Old Power House (Sialkot)	132/11.5KV, 20/26MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	18/9/17	1200 To 1600	All O/G feeders of power T/F T-2 will be affected.

15	132KV G/S Kharian	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	20/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
16	132KV G/S Kharian	132/11.5KV, 20/26MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	20/9/17	1200 To 1600	All O/G feeders of power T/F T-2 will be affected.
17	132KV G/S Lalapur	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	21/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
18	132KV G/S Lalapur	132/11.5KV, 10/13MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	21/9/17	1200 to 1600	All O/G feeders of power T/F T-2 will be affected.
19	132KV G/S Cantt Sialkot	132/11KV 31.5/40MVA P.T/F T-1 (Make PEL)	For special maintenance & testing of P.T/F along with 11KV bus bar.	22/9/17	0900 to 1200	All O/G feeders of T-1 will be affected.
20	132KV G/S M.B Din	132/11.5KV, 20/26MVA P.T/F T-1 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	23/9/17	0900 To 1300	All O/G feeders of power T/F T-1 will be affected.
21	132KV G/S M.B Din	132/11.5KV, 20/26MVA P.T/F T-2 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	23/9/17	1200 To 1600	All O/G feeders of power T/F T-2 will be affected.
22	132KV G/S Old Power House (Sialkot)	132/11.5KV, 20/26MVA P.T/F T-3 along with bay, 11KV bus bar and switch gears	For annual maintenance and testing of protection system.	25/9/17	0900 To 1300	All O/G feeders of power T/F T-3 will be affected.
23	132KV G/S Old Power House (Sialkot)	132KV C.B OPH-1	For annual maintenance and testing of protection system.	25/9/17	1300 TO 1500	NIL
24	132KV G/S Old Power House (Sialkot)	132KV C.B OPH-2	For annual maintenance and testing of protection system.	25/9/17	1500 TO 1700	NIL
25	132KV G/S J.P. Jattan	132/11KV 31.5/40MVA P.T/F T-1 (Make PEL)	For special maintenance & testing of P.T/F along with 11KV bus bar.	26/9/17	0900 to 1200	All O/G feeders of T-3 will be affected.
26	132KV G/S Lalamusa	132/11.5KV, 31.5/40MVA P.T/F T-3 along with bay, 11KV bus bar and switch gears	For special + annual maintenance & testing of P.T/F along with 11KV bus bar.	27/9/17	0900 to 1300	All O/G feeders of T-3 will be affected.
27	132KV G/S Lalamusa	132KV C.B LLM-2	For annual maintenance and testing of protection system.	27/9/17	1300 to 1500	NIL
28	132KV G/S Lalamusa	132KV C.B LLM-3	For annual maintenance and testing of protection system.	27/9/17	1500 to 1700	NIL
29	132KV G/S K/Shiekhan	132/11KV 31.5/40MVA P.T/F T-3 (Make PEL)	For special maintenance & testing of P.T/F along with 11KV bus bar.	28/9/17	0900 to 1200	All O/G feeders of T-3 will be affected.

The work must be completed within the scheduled period of shut down without fail.

This issues with the approval of Chief Engineer (Operation) GEPCO Gujranwala.

**Note:- The copies of press clipping showing shut down in the Newspapers alongwith copy of PTW must be provided to this office.**

  
**(SHAHID PERVAIZ)**  
**DEPUTY DIRECTOR O&M (DIST.)**  
**GEPCO, GUJRANWALA**

**CC:-By Fax:**

1. S.E's (Op.) Circles GEPCO Sialkot & Gujrat with the request to direct the XEN's (Op.) Concerned for carrying out maintenance during the said shut down. He is also requested to arrange publishing of news of Shut Downs in local as well as National Press well in time. The exact nature of work must be given in the news of shut down.
2. S.E (GSO) Circle GEPCO Gujranwala for information please.
3. Addl: Assistant Manager (MIS) GEPCO H/Q Gujranwala for incorporating in GEPCO web-site please.
4. Dy. Director (Safety) GEPCO, Gujranwala for information please.
5. Dy. Director (PR) GEPCO, Gujranwala for further neseccery action please.
6. Deputy Manager PDC GEPCO Shaheenabad Gujranwala. He is requested to exempt load shedding of above feeders if possible in the prevailing load shedding program for the period they remained under PTW.
7. Dunya News, Paracha Centre, Shaheenabad Gujranwala.
8. Khabrain Office, Civil Lines, Opposite Punjab Provincial Cooperative Office, Gujranwala.