

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
1	132 KV Shaheen Abad GRW	D.C ROAD	5018	Domestic Urban	GUJRANWALA	I	6:00	0:59	5:01	DUE TO OVER LOADING OF 500KV NOKHAR.
2	132 KV Shaheen Abad GRW	SHAMAH COLONY	5032	Domestic Urban	GUJRANWALA	I	6:00	0:58	5:02	DUE TO OVER LOADING OF 500KV NOKHAR.
3	132 KV Shaheen Abad GRW	MODEL TOWN	5011	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	DUE TO OVER LOADING OF 500KV NOKHAR.
4	132 KV Shaheen Abad GRW	SESSION COURT	5040	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	DUE TO OVER LOADING OF 500KV NOKHAR.
5	132 KV Shaheen Abad GRW	CIVIL LINES	5012	Domestic Urban	GUJRANWALA	I	6:00	1:05	4:55	EMERGENCY PTW
6	132 KV Shaheen Abad GRW	AHMED PURA	5035	Domestic Urban	GUJRANWALA	I	6:00	0:30	5:30	DUE TO OVER LOADING OF 500KV NOKHAR.
7	132 KV Shaheen Abad GRW	HOSPITAL ROAD	5016	Domestic Urban	GUJRANWALA	I	6:00	1:32	4:28	EMERGENCY PTW
8	132 KV Shaheen Abad GRW	SUI GAS ROAD	5010	Domestic Urban	GUJRANWALA	I	6:00	0:56	5:04	DUE TO OVER LOADING OF 500KV NOKHAR.
9	132 KV Shaheen Abad GRW	GONDLANWALA ROAD	5019	Domestic Urban	GUJRANWALA	I	6:00	0:54	5:06	DUE TO OVER LOADING OF 500KV NOKHAR.
10	132 KV Shaheen Abad GRW	SHEHEENABAD	5017	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	DUE TO OVER LOADING OF 500KV NOKHAR.
11	132 KV Shaheen Abad GRW	MADINA COLONY	5039	Domestic Urban	GUJRANWALA	I	6:00	0:56	5:04	DUE TO OVER LOADING OF 500KV NOKHAR.
12	132 KV College Road GRW	B B PURA	3201	Domestic Urban	GUJRANWALA	I	6:00	2:36	3:24	DUE TO OVER LOADING OF 500KV NOKHAR.
13	132 KV College Road GRW	REHMAN PURA	3209	Domestic Urban	GUJRANWALA	I	6:00	2:16	3:44	DUE TO OVER LOADING OF 500KV NOKHAR.
14	132 KV College Road GRW	ALAM CHOWK	3231	Domestic Urban	GUJRANWALA	I	6:00	1:46	4:14	DUE TO OVER LOADING OF 500KV NOKHAR.
15	132 KV College Road GRW	NEW JINAH ROAD	3227	Domestic Urban	GUJRANWALA	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
16	132 KV College Road GRW	GUJRANWALA 3	3221	Domestic Urban	GUJRANWALA	I	6:00	1:33	4:27	DUE TO OVER LOADING OF 500KV NOKHAR.
17	132 KV College Road GRW	SHALIMAR TOWN	3219	Domestic Urban	GUJRANWALA	I	6:00	2:08	3:52	DUE TO OVER LOADING OF 500KV NOKHAR.
18	132 KV College Road GRW	CLOCK TOWER	3212	Domestic Urban	GUJRANWALA	I	6:00	2:15	3:45	DUE TO OVER LOADING OF 500KV NOKHAR.
19	132 KV College Road GRW	GULSHANABAD	3220	Domestic Urban	GUJRANWALA	I	6:00	1:26	4:34	DUE TO OVER LOADING OF 500KV NOKHAR.
20	132 KV College Road GRW	LAHORE ROAD	3228	Domestic Urban	GUJRANWALA	I	6:00	1:49	4:11	DUE TO OVER LOADING OF 500KV NOKHAR.
21	132 KV College Road GRW	QAZAFI ROAD	3230	Domestic Urban	GUJRANWALA	I	6:00	1:42	4:18	DUE TO OVER LOADING OF 500KV NOKHAR.
22	132 KV Hafiz Abad Road GRW	AWAN CHOWK	81402	Domestic Urban	GUJRANWALA	I	6:00	0:54	5:06	DUE TO OVER LOADING OF 500KV NOKHAR.
23	132 KV Hafiz Abad Road GRW	WARRIACH	81407	Domestic Urban	GUJRANWALA	I	6:00	22:10	16:10	MONITORING SYSTEM ERROR

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
24	132 KV Hafiz Abad Road GRW	NEW B B PURA	81420	Domestic Urban	GUJRANWALA	I	6:00	1:14	4:46	DUE TO OVER LOADING OF 500KV NOKHAR.
25	132 KV Cantt. GRW	GARDEN TOWN	95414	Domestic Urban	GUJRANWALA	I	6:00	3:03	2:57	DUE TO OVER LOADING OF 500KV NOKHAR.
26	132 KV Cantt. GRW	DC COLONY	95402	Domestic Urban	GUJRANWALA	I	6:00	2:01	3:59	DUE TO OVER LOADING OF 500KV NOKHAR.
27	132 KV Cantt. GRW	RAHWALI	95403	Domestic Urban	GUJRANWALA	I	6:00	2:11	3:49	DUE TO OVER LOADING OF 500KV NOKHAR.
28	132 KV Cantt. GRW	DC COLONY 3	95411	Domestic Urban	GUJRANWALA	I	6:00	2:00	4:00	DUE TO OVER LOADING OF 500KV NOKHAR.
29	132 KV Cantt. GRW	DC COLONY 1	95409	Domestic Urban	GUJRANWALA	I	6:00	2:18	3:42	DUE TO OVER LOADING OF 500KV NOKHAR.
30	132 KV Cantt. GRW	ALLAMA IQBAL TOWN	95412	Domestic Urban	GUJRANWALA	I	6:00	1:04	4:56	DUE TO OVER LOADING OF 500KV NOKHAR.
31	132 KV Cantt. GRW	NEW LOHIANWALA		Domestic Urban	GUJRANWALA	I	6:00	1:05	4:55	DUE TO OVER LOADING OF 500KV NOKHAR.
32	132 KV Cantt. GRW	SHARIF FARM	95401	Domestic Urban	GUJRANWALA	I	6:00	3:35	2:25	DUE TO OVER LOADING OF 500KV NOKHAR.
33	132 KV Cantt. GRW	DC COLONY 2	95410	Domestic Urban	GUJRANWALA	I	6:00	1:59	4:01	DUE TO OVER LOADING OF 500KV NOKHAR.
34	132 KV Cantt. GRW	DEFENCE	95416	Domestic Urban	GUJRANWALA	I	6:00	2:49	3:11	DUE TO OVER LOADING OF 500KV NOKHAR.
35	132 KV Lahore Road GRW	CANAL VIEW-1	72515	Domestic Urban	GUJRANWALA	I	6:00	1:18	4:42	DUE TO OVER LOADING OF 500KV NOKHAR.
36	132 KV Lahore Road GRW	CANAL VIEW-2	72516	Domestic Urban	GUJRANWALA	I	6:00	1:00	5:00	DUE TO OVER LOADING OF 500KV NOKHAR.
37	132 KV Lahore Road GRW	CITY HOUSING SCHEME	72523	Domestic Urban	GUJRANWALA	I	6:00	11:12	5:12	NO-NOMINAL LOAD
38	132 KV Lahore Road GRW	WAPDA TOWN EAST	72501	Domestic Urban	GUJRANWALA	I	6:00	1:50	4:10	DUE TO OVER LOADING OF 500KV NOKHAR.
39	132 KV Lahore Road GRW	WAPDA TOWN WEST	72502	Domestic Urban	GUJRANWALA	I	6:00	0:59	5:01	DUE TO OVER LOADING OF 500KV NOKHAR.
40	132 KV Pasrur Road GRW	PROFESSOR TOWN	15720	Domestic Urban	GUJRANWALA	I	6:00	1:27	4:33	DUE TO OVER LOADING OF 500KV NOKHAR.
41	132 KV Pasrur Road GRW	NEW POPULAR NURSERY	15727	Domestic Urban	GUJRANWALA	I	6:00	1:49	4:11	DUE TO OVER LOADING OF 500KV NOKHAR.
42	132 KV Pasrur Road GRW	WAHDAT COLY	15704	Domestic Urban	GUJRANWALA	I	6:00	0:27	5:33	TRIPPING
43	132 KV Pasrur Road GRW	SIALKOT ROAD	15711	Domestic Urban	GUJRANWALA	I	6:00	0:49	5:11	DUE TO OVER LOADING OF 500KV NOKHAR.
44	132 KV Pasrur Road GRW	KHOKHER KEE	15728	Domestic Urban	GUJRANWALA	I	6:00	1:31	4:29	DUE TO OVER LOADING OF 500KV NOKHAR.
45	132 KV Pasrur Road GRW	FEROZWALA ROAD	15716	Domestic Urban	GUJRANWALA	I	6:00	1:00	5:00	DUE TO OVER LOADING OF 500KV NOKHAR.
46	132 KV Pasrur Road GRW	NEW SIALKOT ROAD	15726	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	RELIEF BY RCC
47	132 KV Pasrur Road GRW	11 KV MADNI ROAD	15723	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
48	132 KV Pasrur Road GRW	CANAL(015719)	15719	Domestic Urban	GUJRANWALA	I	6:00	1:29	4:31	DUE TO OVER LOADING OF 500KV NOKHAR.
49	132 KV Theri Sansi	FAISAL COLONY	21404	Domestic Urban	GUJRANWALA	I	6:00	0:23	5:37	DUE TO OVER LOADING OF 500KV NOKHAR.
50	132 KV Theri Sansi	INDUSTRIAL(T- SANSI)	21409	Domestic Urban	GUJRANWALA	I	6:00	1:37	4:23	DUE TO OVER LOADING OF 500KV NOKHAR.
51	132 KV Theri Sansi	G.T.ROAD-2(T- SANSI)	21410	Domestic Urban	GUJRANWALA	I	6:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
52	132 KV Wazirabad	ALLAHABAD	22218	Domestic Urban	WAZIR ABAD	I	6:00	2:36	3:24	DUE TO OVER LOADING OF 500KV NOKHAR.
53	132 KV Wazirabad	NIZAM ABAD	22205	Domestic Urban	WAZIR ABAD	I	6:00	2:56	3:04	DUE TO OVER LOADING OF 500KV NOKHAR.
54	132 KV Wazirabad	HAJI PURA	22216	Domestic Urban	WAZIR ABAD	I	6:00	2:41	3:19	DUE TO OVER LOADING OF 500KV NOKHAR.
55	132 KV Gujrat-I	SARGODHA ROAD	5101	Domestic Urban	GUJRAT	I	6:00	9:48	3:48	LOAD REDUCED
56	132 KV Gujrat-I	SHAH DAULA	5112	Domestic Urban	GUJRAT	I	6:00	2:28	3:32	DUE TO OVER LOADING OF 500KV NOKHAR.
57	132 KV Gujrat-I	EID GAH	5117	Domestic Urban	GUJRAT	I	6:00	2:48	3:12	DUE TO OVER LOADING OF 500KV NOKHAR.
58	132 KV Gujrat-I	GEPCO COMPLEX	5118	Domestic Urban	GUJRAT	I	6:00	2:37	3:23	DUE TO OVER LOADING OF 500KV NOKHAR.
59	132 KV Gujrat-I	RAILWAY ROAD	5113	Domestic Urban	GUJRAT	I	6:00	2:42	3:18	DUE TO OVER LOADING OF 500KV NOKHAR.
60	132 KV Gujrat-I	SABOWAL	5110	Domestic Urban	GUJRAT	I	6:00	1:52	4:08	DUE TO OVER LOADING OF 500KV NOKHAR.
61	132 KV Gujrat-I	DHOOL	5102	Domestic Urban	GUJRAT	I	6:00	1:53	4:07	DUE TO OVER LOADING OF 500KV NOKHAR.
62	132 KV Kharian	KHARIAN CANTT	10703	Domestic Urban	KHARIAN	I	6:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
63	132 KV Kharian	I.J CANTT.	10709	Domestic Urban	KHARIAN	I	6:00	5:03	0:57	DUE TO OVER LOADING OF 500KV NOKHAR.
64	132 KV Kharian	NEW KHARIAN CANTT	10705	Domestic Urban	KHARIAN	I	6:00	0:00	6:00	RELIEF BY RCC
65	132 KV FatehPur	ALI PUR	27301	Domestic Urban	ALI PUR	I	6:00	5:29	0:31	BREAK DOWN
66	132 KV FatehPur	CITY FEEDER	27308	Domestic Urban	ALI PUR	I	6:00	2:57	3:03	DUE TO OVER LOADING OF 500KV NOKHAR.
67	132 KV Aroop GRW	PRIME CITY	97412	Domestic Urban	GUJRANWALA	I	6:00	1:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
68	132 KV Aroop GRW	JOHAR TOWN	97413	Domestic Urban	GUJRANWALA	I	6:00	1:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
69	132 KV Gujrat-II	CIRCULAR ROAD	46915	Domestic Urban	GUJRAT	I	6:00	3:50	2:10	DUE TO OVER LOADING OF 500KV NOKHAR.
70	132 KV Gujrat-II	JAIL ROAD	46914	Domestic Urban	GUJRAT	I	6:00	2:59	3:01	BREAK DOWN
71	132 KV Gujrat-II	MADINA	46916	Domestic Urban	GUJRAT	I	6:00	10:47	4:47	MONITORING SYSTEM ERROR
72	132 KV Gujrat-II	SHADMAN	46920	Domestic Urban	GUJRAT	I	6:00	3:49	2:11	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
73	132 KV Gujrat-II	FAIZAN-E-MADINA	46919	Domestic Urban	GUJRAT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
74	132 KV Lala Musa	DHAMA ROAD	11614	Domestic Urban	LALA MUSA	I	6:00	3:55	2:05	DUE TO OVER LOADING OF 500KV NOKHAR.
75	132 KV Lala Musa	KAKA SAHIB	11606	Domestic Urban	LALA MUSA	I	6:00	3:35	2:25	DUE TO OVER LOADING OF 500KV NOKHAR.
76	132 KV Lala Musa	PAK PUR	11604	Domestic Urban	LALA MUSA	I	6:00	4:07	1:53	DUE TO OVER LOADING OF 500KV NOKHAR.
77	132 KV Hafizabad	GHARI AWAN(HFD-2)	5504	Domestic Urban	HAFIZ ABAD	I	6:00	5:45	0:15	APPROVED PTW
78	132 KV Hafizabad	KHAN PURA	5517	Domestic Urban	HAFIZ ABAD	I	6:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
79	132 KV Hafizabad	ALI PUR ROAD	5519	Domestic Urban	HAFIZ ABAD	I	6:00	4:05	1:55	FORCE BY RCC
80	132 KV Hafizabad	DISTRICT COMPLEX	5522	Domestic Urban	HAFIZ ABAD	I	6:00	2:07	3:53	FORCE BY RCC
81	132 KV Hafizabad	GUJRANWALA ROAD	5505	Domestic Urban	HAFIZ ABAD	I	6:00	0:00	6:00	RELIEF BY RCC
82	132 KV Qila Didar Singh	ISLAM PURA	16312	Domestic Urban	QILA DIDAR SINGH	I	6:00	4:05	1:55	DUE TO OVER LOADING OF 500KV NOKHAR.
83	132 KV Dinga	DINGA CITY	64401	Domestic Urban	DINGA	I	6:00	4:46	1:14	APPROVED PTW
84	132 KV Dinga	THANA ROAD	64405	Domestic Urban	DINGA	I	6:00	3:35	2:25	DUE TO OVER LOADING OF 500KV NOKHAR.
85	132 KV Mangowal	KUNJAH	62306	Domestic Urban	GUJRAT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
86	132 KV Pindi Bhattian	PINDI BHATTIAN CITY	44601	Domestic Urban	PINDI BHATTIAN	I	6:00	0:30	5:30	TRIPPING
87	132 KV Pindi Bhattian	LAHORE ROAD	44608	Domestic Urban	PINDI BHATTIAN	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
88	132 KV Jalal Pur Bhatian	PINDI BHATTIAN ROAD	73807	Domestic Urban	JALAL PUR BHATTIAN	I	6:00	2:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.
89	132 KV New Malakwal	MIANI	32104	Domestic Urban	MALAKWAL	I	6:00	3:38	2:22	DUE TO OVER LOADING OF 500KV NOKHAR.
90	132 KV Kothiala Sheikhan	NEW PHALIA-I	8504	Domestic Urban	PHALIA	I	6:00	3:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
91	132 KV Mandi Bahaudin	GURAH MOHALLAH	63204	Domestic Urban	MANDI BHAUDIN	I	6:00	3:02	2:58	DUE TO OVER LOADING OF 500KV NOKHAR.
92	132 KV Mandi Bahaudin	SUFI CITY	63213	Domestic Urban	MANDI BHAUDIN	I	6:00	2:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
93	132 KV Mandi Bahaudin	CANAL	63206	Domestic Urban	MANDI BHAUDIN	I	6:00	2:48	3:12	DUE TO OVER LOADING OF 500KV NOKHAR.
94	132 KV Mandi Bahaudin	WASU	63209	Domestic Urban	MANDI BHAUDIN	I	6:00	3:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
95	132 KV Narowal	PHATA	14219	Domestic Urban	NAROWAL	I	6:00	23:57	17:57	MONITORING SYSTEM ERROR
96	132 KV Narowal	GHOUSIA	14210	Domestic Urban	NAROWAL	I	6:00	0:00	6:00	RELIEF BY RCC
97	132 KV Daska Industrial	PASRUR ROAD	60022	Domestic Urban	DASKA	I	6:00	4:01	1:59	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
98	132 KV Daska Industrial	DASKA NO-3	60006	Domestic Urban	DASKA	I	6:00	4:00	2:00	DUE TO OVER LOADING OF 500KV NOKHAR.
99	132 KV Pasrur	GODHA	34308	Domestic Urban	PASRUR	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
100	132 KV Pasrur	ARMY CANTONMENT	34313	Domestic Urban	PASRUR	I	6:00	2:27	3:33	DUE TO OVER LOADING OF 500KV NOKHAR.
101	132 KV Ghuinki	ADHA	96904	Domestic Urban	SIALKOT	I	6:00	5:11	0:49	DUE TO OVER LOADING OF 500KV NOKHAR.
102	132 KV Ghuinki	CITY HOUSING SCHEME	96911	Domestic Urban	SIALKOT	I	6:00	5:07	0:53	DUE TO OVER LOADING OF 500KV NOKHAR.
103	132 KV Lala Pur	CHAWINDA CITY	82303	Domestic Urban	CHAWINDA	I	6:00	4:18	1:42	DUE TO OVER LOADING OF 500KV NOKHAR.
104	132 KV Lala Pur	CHAWINDA-II	82309	Domestic Urban	CHAWINDA	I	6:00	4:26	1:34	DUE TO OVER LOADING OF 500KV NOKHAR.
105	132 KV Daska City	HAJI PURA	26314	Domestic Urban	DASKA	I	6:00	2:18	3:42	DUE TO OVER LOADING OF 500KV NOKHAR.
106	132 KV Daska City	DASKA NO.1	26303	Domestic Urban	DASKA	I	6:00	2:18	3:42	DUE TO OVER LOADING OF 500KV NOKHAR.
107	132 KV Daska City	DASKA NO.2	26304	Domestic Urban	DASKA	I	6:00	2:44	3:16	DUE TO OVER LOADING OF 500KV NOKHAR.
108	132 KV Shakhar Garh	CITY-3 SHAKARGARH	80213	Domestic Urban	SHAKARGARH	I	6:00	0:00	6:00	RELIEF BY RCC
109	132 KV Pasrur Road Sialkot	NAIKAPURA	20115	Domestic Urban	SIALKOT	I	6:00	2:15	3:45	DUE TO OVER LOADING OF 500KV NOKHAR.
110	132 KV Pasrur Road Sialkot	ISLAMABAD	20117	Domestic Urban	SIALKOT	I	6:00	0:56	5:04	DUE TO OVER LOADING OF 500KV NOKHAR.
111	132 KV Pasrur Road Sialkot	RANG PURA	20109	Domestic Urban	SIALKOT	I	6:00	2:17	3:43	DUE TO OVER LOADING OF 500KV NOKHAR.
112	132 KV Pasrur Road Sialkot	PURA HIRAN	20114	Domestic Urban	SIALKOT	I	6:00	1:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
113	132 KV Pasrur Road Sialkot	HUNDAL	20103	Domestic Urban	SIALKOT	I	6:00	1:30	4:30	DUE TO OVER LOADING OF 500KV NOKHAR.
114	132 KV Pasrur Road Sialkot	IMAM SAHIB	20108	Domestic Urban	SIALKOT	I	6:00	5:39	0:21	APPROVED PTW
115	132 KV Pasrur Road Sialkot	HABIB PURA	20105	Domestic Urban	SIALKOT	I	6:00	5:39	0:21	APPROVED PTW
116	132 KV Sialkot City	SHAHAB ROAD	37518	Domestic Urban	SIALKOT	I	6:00	2:20	3:40	DUE TO OVER LOADING OF 500KV NOKHAR.
117	132 KV Sialkot City	GHAUSE PURA	37525	Domestic Urban	SIALKOT	I	6:00	1:41	4:19	DUE TO OVER LOADING OF 500KV NOKHAR.
118	132 KV Sialkot City	FATEH GARH	37520	Domestic Urban	SIALKOT	I	6:00	5:55	0:05	DUE TO OVER LOADING OF 500KV NOKHAR.
119	132 KV Sialkot City	MUBARIK PURA	37503	Domestic Urban	SIALKOT	I	6:00	2:02	3:58	DUE TO OVER LOADING OF 500KV NOKHAR.
120	132 KV Sialkot City	CHAND CHOWK	37527	Domestic Urban	SIALKOT	I	6:00	0:59	5:01	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
121	132 KV Sialkot City	MALIK SHAH WALI	37529	Domestic Urban	SIALKOT	I	6:00	2:16	3:44	DUE TO OVER LOADING OF 500KV NOKHAR.
122	132 KV Sialkot New	MURAD PUR	44413	Domestic Urban	SIALKOT	I	6:00	1:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
123	132 KV Sialkot New	KHOKHAR TOWN	44422	Domestic Urban	SIALKOT	I	6:00	2:01	3:59	DUE TO OVER LOADING OF 500KV NOKHAR.
124	132 KV Sialkot New	NANGAL	44421	Domestic Urban	SIALKOT	I	6:00	3:15	2:45	DUE TO OVER LOADING OF 500KV NOKHAR.
125	132 KV Sialkot New	MUZAFFAR PUR	44410	Domestic Urban	SIALKOT	I	6:00	2:17	3:43	DUE TO OVER LOADING OF 500KV NOKHAR.
126	132 KV Sialkot New	IQBAL TOWN	44415	Domestic Urban	SIALKOT	I	6:00	1:56	4:04	DUE TO OVER LOADING OF 500KV NOKHAR.
127	132 KV Sialkot New	MUSLIM TOWN	44420	Domestic Urban	SIALKOT	I	6:00	1:49	4:11	DUE TO OVER LOADING OF 500KV NOKHAR.
128	132 KV Sialkot New	MALKAY KALAN	44412	Domestic Urban	SIALKOT	I	6:00	2:01	3:59	DUE TO OVER LOADING OF 500KV NOKHAR.
129	132 KV Sialkot New	MODEL TOWN	44423	Domestic Urban	SIALKOT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
130	132 KV Sialkot New	BUTTER	44405	Domestic Urban	SIALKOT	I	6:00	0:58	5:02	DUE TO OVER LOADING OF 500KV NOKHAR.
131	132 KV Sialkot New	MIANAPURA	44416	Domestic Urban	SIALKOT	I	6:00	1:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
132	132 KV Sialkot New	KASHMIR ROAD	44419	Domestic Urban	SIALKOT	I	6:00	0:59	5:01	DUE TO OVER LOADING OF 500KV NOKHAR.
133	132 KV Sialkot New	MARALA ROAD	44406	Domestic Urban	SIALKOT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
134	132 KV Sialkot Cantt	BALANWALA	51108	Domestic Urban	SIALKOT	I	6:00	1:36	4:24	DUE TO OVER LOADING OF 500KV NOKHAR.
135	132 KV Sialkot Cantt	KHAROTA SYDAN-2	51111	Domestic Urban	SIALKOT	I	6:00	6:52	0:52	APPROVED PTW
136	132 KV Sialkot Cantt	COURT ROAD	51118	Domestic Urban	SIALKOT	I	6:00	2:47	3:13	DUE TO OVER LOADING OF 500KV NOKHAR.
137	132 KV Sialkot Cantt	CLOCK TOWER	51112	Domestic Urban	SIALKOT	I	6:00	3:14	2:46	BREAK DOWN
138	132 KV Sialkot Cantt	PARIS ROAD	51103	Domestic Urban	SIALKOT	I	6:00	1:59	4:01	DUE TO OVER LOADING OF 500KV NOKHAR.
139	132 KV Sialkot Cantt	GUL BAHAR	51120	Domestic Urban	SIALKOT	I	6:00	2:29	3:31	DUE TO OVER LOADING OF 500KV NOKHAR.
140	132 KV Sialkot Cantt	CHRISTIAN TOWN	51115	Domestic Urban	SIALKOT	I	6:00	1:13	4:47	DUE TO OVER LOADING OF 500KV NOKHAR.
141	132 KV Sialkot Cantt	M.E.S	51105	Domestic Urban	SIALKOT	I	6:00	2:33	3:27	DUE TO OVER LOADING OF 500KV NOKHAR.
142	132 KV Sialkot Cantt	BHIRTH	51119	Domestic Urban	SIALKOT	I	6:00	1:53	4:07	DUE TO OVER LOADING OF 500KV NOKHAR.
143	132 KV Sialkot Cantt	SADAR BAZAR	51106	Domestic Urban	SIALKOT	I	6:00	2:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
144	132 KV Sialkot Cantt	ASKARI	51113	Domestic Urban	SIALKOT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
145	132 KV Sialkot Cantt	M.E.S (051116)	51116	Domestic Urban	SIALKOT	I	6:00	2:28	3:32	DUE TO OVER LOADING OF 500KV NOKHAR.
146	132 KV Sambrial	SAMBRIAL-3	18712	Domestic Urban	SAMBRIAL	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
147	220 KV Ghakkhar - 220 kV	GHAKKHAR NEW	4414	Domestic Urban	GUJRANWALA	I	6:00	4:08	1:52	DUE TO OVER LOADING OF 500KV NOKHAR.
148	220 KV Ghakkhar - 220 kV	ASKERI	4419	Domestic Urban	GUJRANWALA	I	6:00	4:00	2:00	DUE TO OVER LOADING OF 500KV NOKHAR.
149	220 KV Ghakkhar - 220 kV	GRW.CANTT-1	4417	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	DUE TO OVER LOADING OF 500KV NOKHAR.
150	220 KV Ghakkhar - 220 kV	GRW.CANTT-2	4404	Domestic Urban	GUJRANWALA	I	6:00	0:04	5:56	DUE TO OVER LOADING OF 500KV NOKHAR.
151	220 KV Ghakkhar - 220 kV	S.S. BOARD	4409	Domestic Urban	GUJRANWALA	I	6:00	5:26	0:34	DUE TO OVER LOADING OF 500KV NOKHAR.
152	220 KV Sahawal Sialkot-220kV	UGGOKI	81305	Domestic Urban	SIALKOT	I	6:00	3:10	2:50	DUE TO OVER LOADING OF 500KV NOKHAR.
153	220 KV Sahawal Sialkot-220kV	BHOPALWALA	81302	Domestic Urban	SIALKOT	I	6:00	4:25	1:35	DUE TO OVER LOADING OF 500KV NOKHAR.
154	132 KV Ratti Gujrat	KALRA	108101	Domestic Urban	GUJRAT	I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
155	132 KV Ratti Gujrat	AHMAD ABAD	108104	Domestic Urban	GUJRAT	I	6:00	1:53	4:07	DUE TO OVER LOADING OF 500KV NOKHAR.
156	132 KV Ratti Gujrat	GULZAR-E-MADINA	108108	Domestic Urban	GUJRAT	I	6:00	1:42	4:18	DUE TO OVER LOADING OF 500KV NOKHAR.
157	132 KV Phalia	PHALIA CITY	108001	Domestic Urban	PHALIA	I	6:00	0:32	5:28	DUE TO OVER LOADING OF 500KV NOKHAR.
158	132 KV Phalia	GUJRAT ROAD	108008	Domestic Urban	PHALIA	I	6:00	0:00	6:00	RELIEF BY RCC
159	132 KV Hafiz Abad-II	HASSAN TOWN	108601	Domestic Urban	HAFIZ ABAD	I	6:00	1:50	4:10	DUE TO OVER LOADING OF 500KV NOKHAR.
160	132 KV OPH Sialkot	IMAM SHAB-1	109406	Domestic Urban	SIALKOT	I	6:00	1:16	4:44	DUE TO OVER LOADING OF 500KV NOKHAR.
161	132 KV OPH Sialkot	CIRCULAR RD-1	109407	Domestic Urban	SIALKOT	I	6:00	2:17	3:43	DUE TO OVER LOADING OF 500KV NOKHAR.
162	132 KV OPH Sialkot	BOGRAH	109405	Domestic Urban	SIALKOT	I	6:00	2:02	3:58	DUE TO OVER LOADING OF 500KV NOKHAR.
163	132 KV Daska New	GULISTAN COLONY	110211	Domestic Urban	DASKA	I	6:00	4:05	1:55	DUE TO OVER LOADING OF 500KV NOKHAR.
164	132 KV Daska New	SAMBRIAL ROAD	110209	Domestic Urban	DASKA	I	6:00	0:00	6:00	RELIEF BY RCC
165	132 KV Daska New	GHANI PURA	110204	Domestic Urban	DASKA	I	6:00	5:03	0:57	DUE TO OVER LOADING OF 500KV NOKHAR.
166	132 KV Daska New	MODEL TOWN	110210	Domestic Urban	DASKA	I	6:00	4:07	1:53	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
167	132 KV Sheranwala Bagh	MUSLIM ROAD	111902	Domestic Urban	GUJRANWALA	I	6:00	0:00	6:00	RELIEF BY RCC
168	132 KV Sheranwala Bagh	BAKHTAY WALA	111904	Domestic Urban	GUJRANWALA	I	6:00	2:01	3:59	DUE TO OVER LOADING OF 500KV NOKHAR.
169	132 KV Sheranwala Bagh	NOOR BAWA	111911	Domestic Urban	GUJRANWALA	I	6:00	1:18	4:42	DUE TO OVER LOADING OF 500KV NOKHAR.
170	132 KV Sheranwala Bagh	MEHAR NOOR WALA GALA	111912	Domestic Urban	GUJRANWALA	I	6:00	2:20	3:40	DUE TO OVER LOADING OF 500KV NOKHAR.
171	132 KV Sheranwala Bagh	MUJAHID PURA	111913	Domestic Urban	GUJRANWALA	I	6:00	5:01	0:59	APPROVED PTW
172	132 KV Khialy GRW	GULZAR COLONY	112201	Domestic Urban	GUJRANWALA	I	6:00	1:45	4:15	BREAK DOWN
173	132 KV Khialy GRW	NEW FAISAL COLONY	112209	Domestic Urban	GUJRANWALA	I	6:00	0:23	5:37	TRIPPING
174	132 KV Khialy GRW	NOWSHAHRA SANSI	112208	Domestic Urban	GUJRANWALA	I	6:00	0:23	5:37	TRIPPING
175	132 KV Khialy GRW	NEW AWAN CHOWK	112205	Domestic Urban	GUJRANWALA	I	6:00	0:31	5:29	DUE TO OVER LOADING OF 500KV NOKHAR.
176	132 KV Gohad Pur Sialkot	CHITHI SHEIKHAN	115901	Domestic Urban	SIALKOT	I	6:00	1:38	4:22	DUE TO OVER LOADING OF 500KV NOKHAR.
177	132 KV Gohad Pur Sialkot	GOHAD PUR	115903	Domestic Urban	SIALKOT	I	6:00	1:38	4:22	DUE TO OVER LOADING OF 500KV NOKHAR.
178	132 KV Gohad Pur Sialkot	MACHI KHOKHAR	115904	Domestic Urban	SIALKOT	I	6:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
179	132 KV Gohad Pur Sialkot	KAPOOR WALI	115902	Domestic Urban	SIALKOT	I	6:00	4:16	1:44	BREAK DOWN
180	132 KV Gohad Pur Sialkot	NANGLE	115905	Domestic Urban	SIALKOT	I	6:00	2:45	3:15	DUE TO OVER LOADING OF 500KV NOKHAR.
181	132 KV Wazirabad	PHALOKI	22207	Domestic Rural		I	8:00	4:38	3:22	DUE TO OVER LOADING OF 500KV NOKHAR.
182	132 KV Kharian	NEW DHORIA	10710	Domestic Rural		I	8:00	4:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.
183	132 KV Kharian	A.R.SHAHEED	10715	Domestic Rural		I	8:00	4:47	3:13	APPROVED PTW
184	132 KV Kharian	SAEED SHAHEED	10713	Domestic Rural		I	8:00	5:41	2:19	APPROVED PTW
185	132 KV Kharian	KARYALA	10706	Domestic Rural		I	8:00	5:39	2:21	DUE TO OVER LOADING OF 500KV NOKHAR.
186	132 KV Kharian	JANDANWALA	10702	Domestic Rural		I	8:00	4:43	3:17	DUE TO OVER LOADING OF 500KV NOKHAR.
187	132 KV Kharian	MALKAH	10708	Domestic Rural		I	8:00	5:43	2:17	APPROVED PTW
188	132 KV Kharian	RANDHEER	10712	Domestic Rural		I	8:00	5:40	2:20	DUE TO OVER LOADING OF 500KV NOKHAR.
189	132 KV Kharian	NOONANWALI	10704	Domestic Rural		I	8:00	5:33	2:27	DUE TO OVER LOADING OF 500KV NOKHAR.
190	132 KV Gujrat-II	DAULAT NAGAR	46909	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
191	132 KV Gujrat-II	BOKEN SHARIF	46917	Domestic Rural		I	8:00	1:37	6:23	DUE TO OVER LOADING OF 500KV NOKHAR.
192	132 KV Lala Musa	BASCO	11601	Domestic Rural		I	8:00	5:30	2:30	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
193	132 KV Lala Musa	BHAGWAL	11616	Domestic Rural		I	8:00	4:24	3:36	DUE TO OVER LOADING OF 500KV NOKHAR.
194	132 KV Lala Musa	GULIANA	11602	Domestic Rural		I	8:00	5:23	2:37	DUE TO OVER LOADING OF 500KV NOKHAR.
195	132 KV Lala Musa	ALI CHAK	11607	Domestic Rural		I	8:00	4:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.
196	132 KV Lala Musa	UMER CHAK	11615	Domestic Rural		I	8:00	6:37	1:23	DUE TO OVER LOADING OF 500KV NOKHAR.
197	132 KV Lala Musa	MACHIWAL	11612	Domestic Rural		I	8:00	4:37	3:23	DUE TO OVER LOADING OF 500KV NOKHAR.
198	132 KV Lala Musa	KHAWAS PUR	11617	Domestic Rural		I	8:00	3:54	4:06	DUE TO OVER LOADING OF 500KV NOKHAR.
199	132 KV Jalal Pur Jattan	TANDA	6706	Domestic Rural		I	8:00	5:41	2:19	APPROVED PTW
200	132 KV Jalal Pur Jattan	SAGGER JPJ	6708	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
201	132 KV Jalal Pur Jattan	AWAN SHARIF	6709	Domestic Rural		I	8:00	6:39	1:21	DUE TO OVER LOADING OF 500KV NOKHAR.
202	132 KV Jalal Pur Jattan	FATEH PUR	6701	Domestic Rural		I	8:00	4:32	3:28	DUE TO OVER LOADING OF 500KV NOKHAR.
203	132 KV Jalal Pur Jattan	KARIANWALA	6703	Domestic Rural		I	8:00	3:58	4:02	DUE TO OVER LOADING OF 500KV NOKHAR.
204	132 KV Jalal Pur Jattan	KURRY JPJ	6707	Domestic Rural		I	8:00	4:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
205	132 KV Jalal Pur Jattan	BARILA SHARIF	6712	Domestic Rural		I	8:00	5:42	2:18	APPROVED PTW
206	132 KV Bhimber	SADWAL	46712	Domestic Rural		I	8:00	5:28	2:32	APPROVED PTW
207	132 KV Dinga	CHANNAN	64406	Domestic Rural		I	8:00	5:13	2:47	DUE TO OVER LOADING OF 500KV NOKHAR.
208	132 KV Pindi Bhattian	MUSTAFA ABAD	44605	Domestic Rural		I	8:00	0:23	7:37	TRIPPING
209	132 KV Hellan	DINGA	6208	Domestic Rural		I	8:00	5:00	3:00	APPROVED PTW
210	132 KV Hellan	RLY.ST:C/WALA	6213	Domestic Rural		I	8:00	5:25	2:35	DUE TO OVER LOADING OF 500KV NOKHAR.
211	132 KV Kothiala Sheikhan	RUKKAN	8501	Domestic Rural		I	8:00	2:37	5:23	DUE TO OVER LOADING OF 500KV NOKHAR.
212	132 KV Mandi Bahaudin	MONG	63205	Domestic Rural		I	8:00	0:46	7:14	DUE TO OVER LOADING OF 500KV NOKHAR.
213	132 KV Mandi Bahaudin	GULSHAN IQBAL	63202	Domestic Rural		I	8:00	4:05	3:55	DUE TO OVER LOADING OF 500KV NOKHAR.
214	132 KV Narowal	CHANDERKAY	14217	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
215	132 KV Pasrur	MUSA PUR	34306	Domestic Rural		I	8:00	6:01	1:59	APPROVED PTW
216	132 KV Pasrur	KALASWALA	34302	Domestic Rural		I	8:00	6:02	1:58	APPROVED PTW
217	132 KV Ghuinki	BHALOWALI	96909	Domestic Rural		I	8:00	6:08	1:52	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
218	132 KV Ghuinki	KOT MANA (AKBARABAD)	96905	Domestic Rural		I	8:00	5:37	2:23	DUE TO OVER LOADING OF 500KV NOKHAR.
219	132 KV Ghuinki	FAIZUL HASSAN	96901	Domestic Rural		I	8:00	5:02	2:58	DUE TO OVER LOADING OF 500KV NOKHAR.
220	132 KV Ghuinki	TRIGRI SHARIF	96907	Domestic Rural		I	8:00	3:56	4:04	DUE TO OVER LOADING OF 500KV NOKHAR.
221	132 KV Lala Pur	BAJRA GARHI	82308	Domestic Rural		I	8:00	5:13	2:47	BREAK DOWN
222	132 KV Lala Pur	MEHRAJKEY	82302	Domestic Rural		I	8:00	5:34	2:26	DUE TO OVER LOADING OF 500KV NOKHAR.
223	132 KV Lala Pur	CHOBARA	82304	Domestic Rural		I	8:00	5:13	2:47	DUE TO OVER LOADING OF 500KV NOKHAR.
224	132 KV Lala Pur	PINDI BAGHO	82305	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
225	132 KV Shakhar Garh	NANGLE	80208	Domestic Rural		I	8:00	0:06	7:54	TRIPPING
226	132 KV Shakhar Garh	FAIZ AHMAD FAIZ	80209	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
227	132 KV Shakhar Garh	CHAK AMRU	80206	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
228	132 KV Shakhar Garh	BARA MANGA	80207	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
229	132 KV Shakhar Garh	KHAN PUR	80214	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
230	132 KV Shakhar Garh	KURTAR PUR	80215	Domestic Rural		I	8:00	0:07	7:53	TRIPPING
231	132 KV Shakhar Garh	AKHLAS PUR	80210	Domestic Rural		I	8:00	0:26	7:34	TRIPPING
232	132 KV Shakhar Garh	QASIM PUR	80203	Domestic Rural		I	8:00	2:06	5:54	BREAK DOWN
233	132 KV Shakhar Garh	BOSTAN	80205	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
234	132 KV Shakhar Garh	MIR PUR	80212	Domestic Rural		I	8:00	0:42	7:18	BREAK DOWN
235	132 KV Shakhar Garh	NOOR KOT	80211	Domestic Rural		I	8:00	1:40	6:20	BREAK DOWN
236	132 KV Shakhar Garh	GUMTALA	80202	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
237	132 KV Pasrur Road Sialkot	RASOOL PUR BHALLIAN	20110	Domestic Rural		I	8:00	2:32	5:28	DUE TO OVER LOADING OF 500KV NOKHAR.
238	132 KV Pasrur Road Sialkot	LANGREWALI	20112	Domestic Rural		I	8:00	2:27	5:33	DUE TO OVER LOADING OF 500KV NOKHAR.
239	132 KV Baddomalhi	BURJ	91702	Domestic Rural		I	8:00	0:10	7:50	TRIPPING
240	132 KV Baddomalhi	HALLOWAL	91703	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
241	132 KV Baddomalhi	RAYYA	91701	Domestic Rural		I	8:00	0:07	7:53	TRIPPING
242	132 KV Baddomalhi	BHELOWALI	91704	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
243	132 KV Kot Agha	T.BHINDERAN	69806	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
244	132 KV Kot Agha	CHANGA	69804	Domestic Rural		I	8:00	3:40	4:20	DUE TO OVER LOADING OF 500KV NOKHAR.
245	132 KV Kot Agha	SOKEN WIND	69802	Domestic Rural		I	8:00	4:09	3:51	DUE TO OVER LOADING OF 500KV NOKHAR.
246	132 KV Kot Agha	MANGA	69801	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
247	132 KV Kot Agha	JEOIWALI	69803	Domestic Rural		I	8:00	4:43	3:17	DUE TO OVER LOADING OF 500KV NOKHAR.
248	132 KV New Head Marala	BAJWAT-1	32306	Domestic Rural		I	8:00	4:41	3:19	DUE TO OVER LOADING OF 500KV NOKHAR.
249	132 KV New Head Marala	UP STREEM	32305	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
250	132 KV New Head Marala	COLONY(032302)	32302	Domestic Rural		I	8:00	4:43	3:17	DUE TO OVER LOADING OF 500KV NOKHAR.
251	132 KV New Head Marala	BAJWAT-2	32308	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
252	132 KV New Head Marala	CHAPRAR	32307	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
253	132 KV New Head Marala	DOWN STREEM	32303	Domestic Rural		I	8:00	5:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
254	132 KV Zafarwal	KINGRA	40508	Domestic Rural		I	8:00	3:28	4:32	DUE TO OVER LOADING OF 500KV NOKHAR.
255	132 KV Zafarwal	THROMANDI	40502	Domestic Rural		I	8:00	4:35	3:25	DUE TO OVER LOADING OF 500KV NOKHAR.
256	132 KV Zafarwal	JABAL	40504	Domestic Rural		I	8:00	4:33	3:27	BREAK DOWN
257	132 KV Zafarwal	DHAMTHAL	40506	Domestic Rural		I	8:00	4:27	3:33	DUE TO OVER LOADING OF 500KV NOKHAR.
258	132 KV Zafarwal	NONAR	40505	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
259	132 KV Zafarwal	FEROZPUR	40512	Domestic Rural		I	8:00	2:05	5:55	DUE TO OVER LOADING OF 500KV NOKHAR.
260	132 KV Zafarwal	SADWAL	40510	Domestic Rural		I	8:00	3:28	4:32	DUE TO OVER LOADING OF 500KV NOKHAR.
261	132 KV Zafarwal	SANGIAL	40509	Domestic Rural		I	8:00	4:38	3:22	DUE TO OVER LOADING OF 500KV NOKHAR.
262	132 KV Zafarwal	FAKHARUDIN	40513	Domestic Rural		I	8:00	5:33	2:27	DUE TO OVER LOADING OF 500KV NOKHAR.
263	132 KV Zafarwal	DARMAN-I	40501	Domestic Rural		I	8:00	12:49	4:49	MONITORING SYSTEM ERROR
264	132 KV Zafarwal	SANKHATRA	40511	Domestic Rural		I	8:00	4:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
265	132 KV Sialkot Cantt	SAIDPUR	51114	Domestic Rural		I	8:00	2:48	5:12	DUE TO OVER LOADING OF 500KV NOKHAR.
266	132 KV Sialkot Cantt	KUNDAN PUR	51107	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
267	132 KV Sambrial	DHANAWALI	18714	Domestic Rural		I	8:00	5:47	2:13	DUE TO OVER LOADING OF 500KV NOKHAR.
268	132 KV Sambrial	BADOKEY	18713	Domestic Rural		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
269	132 KV Kotli Loharan	KULLOWAL	51004	Domestic Rural		I	8:00	5:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
270	132 KV Kotli Loharan	KHAROTTA SAIDAN-1	51002	Domestic Rural		I	8:00	4:31	3:29	DUE TO OVER LOADING OF 500KV NOKHAR.
271	132 KV Phalia	MANDI ROAD	108002	Domestic Rural		I	8:00	1:16	6:44	BREAK DOWN
272	132 KV Phalia	DHAL	108005	Domestic Rural		I	8:00	0:32	7:28	DUE TO OVER LOADING OF 500KV NOKHAR.
273	132 KV Phalia	BOHAT	108003	Domestic Rural		I	8:00	0:42	7:18	DUE TO OVER LOADING OF 500KV NOKHAR.
274	132 KV Chianwali	CERAMICS -5	108211	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
275	132 KV Chianwali	UPPER CHENAB	108203	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
276	132 KV Chianwali	CHADYALA	108213	Domestic Rural		I	8:00	0:04	7:56	TRIPPING
277	132 KV Awan Sharif	MARJAN	108804	Domestic Rural		I	8:00	5:53	2:07	DUE TO OVER LOADING OF 500KV NOKHAR.
278	132 KV Awan Sharif	JALAL PUR BATTIAN	108806	Domestic Rural		I	8:00	5:37	2:23	DUE TO OVER LOADING OF 500KV NOKHAR.
279	132 KV Awan Sharif	QAZI SULTAN MEHMOOD	108802	Domestic Rural		I	8:00	5:23	2:37	DUE TO OVER LOADING OF 500KV NOKHAR.
280	132 KV Awan Sharif	BUTTER	108803	Domestic Rural		I	8:00	7:19	0:41	DUE TO OVER LOADING OF 500KV NOKHAR.
281	132 KV Awan Sharif	PEER NASIB SHAH	108801	Domestic Rural		I	8:00	5:18	2:42	BREAK DOWN
282	HPS Shadiwal	W/CL SHADIWAL	67002	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
283	66 KV Rasool - 66 kV	DARA PUR	59101	Domestic Rural		I	8:00	0:03	7:57	TRIPPING
284	66 KV Rasool - 66 kV	RASUL	59103	Domestic Rural		I	8:00	0:00	8:00	RELIEF BY RCC
285	132 KV Gohad Pur Sialkot	KHAMBANWALA		Domestic Rural		I	8:00	3:35	4:25	DUE TO OVER LOADING OF 500KV NOKHAR.
286	132 KV College Road GRW	NEW LADHEY WALA CITY	3236	Domestic Urban/Rural		I	6:00	1:18	4:42	DUE TO OVER LOADING OF 500KV NOKHAR.
287	132 KV College Road GRW	KOT QAZI	3206	Domestic Urban/Rural		I	6:00	1:22	4:38	DUE TO OVER LOADING OF 500KV NOKHAR.
288	132 KV College Road GRW	GONDLANWALA	3205	Domestic Urban/Rural		I	6:00	2:45	3:15	DUE TO OVER LOADING OF 500KV NOKHAR.
289	132 KV Hafiz Abad Road GRW	KOT SHERA	81405	Domestic Urban/Rural		I	6:00	2:07	3:53	DUE TO OVER LOADING OF 500KV NOKHAR.
290	132 KV Cantt. GRW	MANDIALA	95405	Domestic Urban/Rural		I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
291	132 KV Lahore Road GRW	KOHLLOWALA	72506	Domestic Urban/Rural		I	6:00	0:41	5:19	DUE TO OVER LOADING OF 500KV NOKHAR.
292	132 KV Lahore Road GRW	MURALIWALI	72520	Domestic Urban/Rural		I	6:00	1:15	4:45	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
293	132 KV Pasrur Road GRW	T.M.KHAN	15718	Domestic Urban/Rural		I	6:00	1:38	4:22	DUE TO OVER LOADING OF 500KV NOKHAR.
294	132 KV Pasrur Road GRW	TOHER	15732	Domestic Urban/Rural		I	6:00	1:41	4:19	DUE TO OVER LOADING OF 500KV NOKHAR.
295	132 KV Pasrur Road GRW	CHAK NAZAM	15709	Domestic Urban/Rural		I	6:00	1:15	4:45	DUE TO OVER LOADING OF 500KV NOKHAR.
296	132 KV Wazirabad	M.Z.A.KHAN	22213	Domestic Urban/Rural		I	6:00	3:06	2:54	DUE TO OVER LOADING OF 500KV NOKHAR.
297	132 KV Gujrat-I	CHENAB	5115	Domestic Urban/Rural		I	6:00	2:33	3:27	DUE TO OVER LOADING OF 500KV NOKHAR.
298	132 KV Gujrat-I	KATHALA	5104	Domestic Urban/Rural		I	6:00	2:43	3:17	DUE TO OVER LOADING OF 500KV NOKHAR.
299	132 KV Kharian	DHORIA	10707	Domestic Urban/Rural		I	6:00	4:48	1:12	DUE TO OVER LOADING OF 500KV NOKHAR.
300	132 KV FatehPur	RASOOL NAGAR	27315	Domestic Urban/Rural		I	6:00	4:53	1:07	DUE TO OVER LOADING OF 500KV NOKHAR.
301	132 KV Aroop GRW	AROOP	97402	Domestic Urban/Rural		I	6:00	0:00	6:00	RELIEF BY RCC
302	132 KV Aroop GRW	NDP-5	97401	Domestic Urban/Rural		I	6:00	0:58	5:02	DUE TO OVER LOADING OF 500KV NOKHAR.
303	132 KV Gujrat-II	JAHANGIR	46910	Domestic Urban/Rural		I	6:00	2:03	3:57	DUE TO OVER LOADING OF 500KV NOKHAR.
304	132 KV Gujrat-II	GAGIAN	46902	Domestic Urban/Rural		I	6:00	3:50	2:10	DUE TO OVER LOADING OF 500KV NOKHAR.
305	132 KV Kamoke	PELLO NO.1	9406	Domestic Urban/Rural		I	6:00	1:18	4:42	BREAK DOWN
306	132 KV Kamoke	PELLO NO.2	9407	Domestic Urban/Rural		I	6:00	0:00	6:00	DUE TO OVER LOADING OF 500KV NOKHAR.
307	132 KV Eminabad	G. T. ROAD(EMINABAD)	50910	Domestic Urban/Rural		I	6:00	5:20	0:40	DUE TO OVER LOADING OF 500KV NOKHAR.
308	132 KV Eminabad	SOHAWA		Domestic Urban/Rural		I	6:00	4:06	1:54	DUE TO OVER LOADING OF 500KV NOKHAR.
309	132 KV Eminabad	RAJA WALA	50902	Domestic Urban/Rural		I	6:00	4:29	1:31	DUE TO OVER LOADING OF 500KV NOKHAR.
310	132 KV Eminabad	EIMIN ABAD TOWN	50901	Domestic Urban/Rural		I	6:00	4:12	1:48	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
311	132 KV Eminabad	CERAMICS	50905	Domestic Urban/Rural		I	6:00	5:34	0:26	DUE TO OVER LOADING OF 500KV NOKHAR.
312	132 KV Bhimber	LANGRIAL	46714	Domestic Urban/Rural		I	6:00	5:09	0:51	DUE TO OVER LOADING OF 500KV NOKHAR.
313	132 KV Bhimber	KOTLA-2	46708	Domestic Urban/Rural		I	6:00	3:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
314	132 KV Bhimber	SABOUR	46715	Domestic Urban/Rural		I	6:00	6:18	0:18	APPROVED PTW
315	132 KV Bhimber	KOTLA-1	46701	Domestic Urban/Rural		I	6:00	5:09	0:51	DUE TO OVER LOADING OF 500KV NOKHAR.
316	132 KV Qila Didar Singh	Q.D.SINGH	16304	Domestic Urban/Rural		I	6:00	4:27	1:33	DUE TO OVER LOADING OF 500KV NOKHAR.
317	132 KV Sukheki	MOCHIWALA(R.BRANCH)	37910	Domestic Urban/Rural		I	6:00	0:23	5:37	TRIPPING
318	132 KV Sukheki	NOTHAIN(N/WANA)	37909	Domestic Urban/Rural		I	6:00	0:57	5:03	DUE TO OVER LOADING OF 500KV NOKHAR.
319	132 KV Sukheki	SUKHEKI(J.BRANCH)	37905	Domestic Urban/Rural		I	6:00	0:27	5:33	DUE TO OVER LOADING OF 500KV NOKHAR.
320	132 KV Kothiala Sheikhan	KUTHIALA SHEIKHAN	8511	Domestic Urban/Rural		I	6:00	5:04	0:56	DUE TO OVER LOADING OF 500KV NOKHAR.
321	132 KV Siranwali	SATRAH	37701	Domestic Urban/Rural		I	6:00	3:28	2:32	DUE TO OVER LOADING OF 500KV NOKHAR.
322	132 KV Mandi Bahaudin	SHAHTAJ	63207	Domestic Urban/Rural		I	6:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
323	132 KV Mandi Bahaudin	JHOLANA	63210	Domestic Urban/Rural		I	6:00	3:52	2:08	DUE TO OVER LOADING OF 500KV NOKHAR.
324	132 KV Pasrur	Q.S.SINGH	34304	Domestic Urban/Rural		I	6:00	2:52	3:08	DUE TO OVER LOADING OF 500KV NOKHAR.
325	132 KV Pasrur	AHMED ABAD	34310	Domestic Urban/Rural		I	6:00	3:56	2:04	DUE TO OVER LOADING OF 500KV NOKHAR.
326	132 KV Ghuinki	PEERO CHAK	96910	Domestic Urban/Rural		I	6:00	4:28	1:32	DUE TO OVER LOADING OF 500KV NOKHAR.
327	132 KV Pasrur Road Sialkot	BHADAL	20104	Domestic Urban/Rural		I	6:00	5:06	0:54	APPROVED PTW
328	132 KV Pasrur Road Sialkot	PAKKI KOTLI	20106	Domestic Urban/Rural		I	6:00	2:56	3:04	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
329	132 KV Baddomalhi	CITY(BADDOMALHI)	91705	Domestic Urban/Rural		I	6:00	0:00	6:00	RELIEF BY RCC
330	132 KV Sialkot Cantt	KAMAN WALA	51104	Domestic Urban/Rural		I	6:00	3:47	2:13	BREAK DOWN
331	132 KV Sialkot Cantt	DALLOWALI	51109	Domestic Urban/Rural		I	6:00	2:02	3:58	DUE TO OVER LOADING OF 500KV NOKHAR.
332	132 KV Sambrial	BEGOWALA	18701	Domestic Urban/Rural		I	6:00	4:08	1:52	DUE TO OVER LOADING OF 500KV NOKHAR.
333	132 KV Kotli Loharan	KOTLI EAST	51003	Domestic Urban/Rural		I	6:00	3:22	2:38	DUE TO OVER LOADING OF 500KV NOKHAR.
334	132 KV Kotli Loharan	KOTLI WEST	51001	Domestic Urban/Rural		I	6:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
335	220 KV Ghakkhar - 220 kV	NAT KALLAN	4407	Domestic Urban/Rural		I	6:00	7:44	1:44	DUE TO OVER LOADING OF 500KV NOKHAR.
336	220 KV Sahawal Sialkot-220kV	CHAK QAZI	81304	Domestic Urban/Rural		I	6:00	4:00	2:00	DUE TO OVER LOADING OF 500KV NOKHAR.
337	220 KV Sahawal Sialkot-220kV	JOURIAN	81306	Domestic Urban/Rural		I	6:00	4:15	1:45	DUE TO OVER LOADING OF 500KV NOKHAR.
338	220 KV Sahawal Sialkot-220kV	SAHOWALA	81301	Domestic Urban/Rural		I	6:00	5:53	0:07	DUE TO OVER LOADING OF 500KV NOKHAR.
339	132 KV Hafiz Abad Road GRW	QILA MIAN SINGH	81406	Rural - T/W Dominated		I	8:00	4:11	3:49	BREAK DOWN
340	132 KV Cantt. GRW	DOGRANWALA	95422	Rural - T/W Dominated		I	8:00	3:07	4:53	BREAK DOWN
341	132 KV Pasrur Road GRW	WANIA	15722	Rural - T/W Dominated		I	8:00	2:35	5:25	DUE TO OVER LOADING OF 500KV NOKHAR.
342	132 KV Wazirabad	KOLAR	22212	Rural - T/W Dominated		I	8:00	5:11	2:49	DUE TO OVER LOADING OF 500KV NOKHAR.
343	132 KV Wazirabad	DHONKAL	22215	Rural - T/W Dominated		I	8:00	4:15	3:45	DUE TO OVER LOADING OF 500KV NOKHAR.
344	132 KV Wazirabad	MURDIKEY	22204	Rural - T/W Dominated		I	8:00	3:24	4:36	DUE TO OVER LOADING OF 500KV NOKHAR.
345	132 KV Wazirabad	SANDAN WALA	22208	Rural - T/W Dominated		I	8:00	5:59	2:01	DUE TO OVER LOADING OF 500KV NOKHAR.
346	132 KV Wazirabad	HEAD KHANKI	22203	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
347	132 KV Wazirabad	NEW HEAD KHANQI	22221	Rural - T/W Dominated		I	8:00	3:56	4:04	DUE TO OVER LOADING OF 500KV NOKHAR.
348	132 KV Wazirabad	PIPLI WALA	22214	Rural - T/W Dominated		I	8:00	4:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.
349	132 KV Wazirabad	FATEH GARH	22201	Rural - T/W Dominated		I	8:00	5:40	2:20	DUE TO OVER LOADING OF 500KV NOKHAR.
350	132 KV Gujrat-I	SHADIWAL	5114	Rural - T/W Dominated		I	8:00	5:22	2:38	EMERGENCY PTW
351	132 KV FatehPur	LUDHAWALA	27309	Rural - T/W Dominated		I	8:00	2:57	5:03	DUE TO OVER LOADING OF 500KV NOKHAR.
352	132 KV FatehPur	KALAIANWALA	27313	Rural - T/W Dominated		I	8:00	2:36	5:24	DUE TO OVER LOADING OF 500KV NOKHAR.
353	132 KV FatehPur	CHINAWAN	27303	Rural - T/W Dominated		I	8:00	4:40	3:20	DUE TO OVER LOADING OF 500KV NOKHAR.
354	132 KV FatehPur	MADAN CHAK	27314	Rural - T/W Dominated		I	8:00	4:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.
355	132 KV FatehPur	BHOMA BATH	27316	Rural - T/W Dominated		I	8:00	4:43	3:17	DUE TO OVER LOADING OF 500KV NOKHAR.
356	132 KV FatehPur	VERPAL	27305	Rural - T/W Dominated		I	8:00	4:42	3:18	DUE TO OVER LOADING OF 500KV NOKHAR.
357	132 KV FatehPur	SAHARAN CHATHA	27312	Rural - T/W Dominated		I	8:00	4:50	3:10	DUE TO OVER LOADING OF 500KV NOKHAR.
358	132 KV FatehPur	MANCHER NEW	27310	Rural - T/W Dominated		I	8:00	5:11	2:49	DUE TO OVER LOADING OF 500KV NOKHAR.
359	132 KV Gujrat-II	JINNAH PUBLIC	46908	Rural - T/W Dominated		I	8:00	3:03	4:57	DUE TO OVER LOADING OF 500KV NOKHAR.
360	132 KV Gujrat-II	CHAK KALA	46918	Rural - T/W Dominated		I	8:00	2:44	5:16	DUE TO OVER LOADING OF 500KV NOKHAR.
361	132 KV Gujrat-II	BIOWALI	46901	Rural - T/W Dominated		I	8:00	3:06	4:54	DUE TO OVER LOADING OF 500KV NOKHAR.
362	132 KV Kamoke	TAMBOLI	9425	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
363	132 KV Kamoke	SHER GARH	9417	Rural - T/W Dominated		I	8:00	0:04	7:56	TRIPPING
364	132 KV Kamoke	SADHOKE	9408	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
365	132 KV Kamoke	DURGA PUR	9401	Rural - T/W Dominated		I	8:00	1:36	6:24	BREAK DOWN
366	132 KV Lala Musa	REHMANI	11609	Rural - T/W Dominated		I	8:00	4:56	3:04	DUE TO OVER LOADING OF 500KV NOKHAR.
367	132 KV Lala Musa	DEENA CHAK	11610	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
368	132 KV Lala Musa	PASWAL	11605	Rural - T/W Dominated		I	8:00	6:08	1:52	DUE TO OVER LOADING OF 500KV NOKHAR.
369	132 KV Nowshera Virkan	MANGOKE	28008	Rural - T/W Dominated		II	8:00	3:40	4:20	DUE TO OVER LOADING OF 500KV NOKHAR.
370	132 KV Nowshera Virkan	MATTA	28011	Rural - T/W Dominated		I	8:00	3:00	5:00	DUE TO OVER LOADING OF 500KV NOKHAR.
371	132 KV Nowshera Virkan	KOT SHERA	28001	Rural - T/W Dominated		I	8:00	6:00	2:00	BREAK DOWN
372	132 KV Nowshera Virkan	BOOPRA	28010	Rural - T/W Dominated		II	8:00	2:56	5:04	DUE TO OVER LOADING OF 500KV NOKHAR.
373	132 KV Nowshera Virkan	KARYAL KALAN	28006	Rural - T/W Dominated		I	8:00	9:39	1:39	DUE TO OVER LOADING OF 500KV NOKHAR.
374	132 KV Nowshera Virkan	BABBER	28009	Rural - T/W Dominated		I	8:00	4:09	3:51	DUE TO OVER LOADING OF 500KV NOKHAR.
375	132 KV Nowshera Virkan	TATLAY ALI	28005	Rural - T/W Dominated		I	8:00	4:53	3:07	DUE TO OVER LOADING OF 500KV NOKHAR.
376	132 KV Nowshera Virkan	SAGO BHAGO	28004	Rural - T/W Dominated		I	8:00	3:37	4:23	DUE TO OVER LOADING OF 500KV NOKHAR.
377	132 KV Nowshera Virkan	MARRI	28007	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
378	132 KV Eminabad	HAMEED PUR	50911	Rural - T/W Dominated		I	8:00	4:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.
379	132 KV Eminabad	KHAN PIARA	50908	Rural - T/W Dominated		I	8:00	4:20	3:40	DUE TO OVER LOADING OF 500KV NOKHAR.
380	132 KV Eminabad	SANSRA	50907	Rural - T/W Dominated		I	8:00	8:14	0:14	APPROVED PTW
381	132 KV Eminabad	ATTA WAH	50903	Rural - T/W Dominated		I	8:00	4:06	3:54	DUE TO OVER LOADING OF 500KV NOKHAR.
382	132 KV Eminabad	MANDIALA TEGA	50904	Rural - T/W Dominated		I	8:00	9:36	1:36	APPROVED PTW

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
383	132 KV Eminabad	11KV LALU PUR	50925	Rural - T/W Dominated		II	8:00	0:00	8:00	RELIEF BY RCC
384	132 KV Jalal Pur Jattan	BHAGOWAL	6713	Rural - T/W Dominated		I	8:00	4:01	3:59	DUE TO OVER LOADING OF 500KV NOKHAR.
385	132 KV Jalal Pur Jattan	SOOK KALAN	6705	Rural - T/W Dominated		I	8:00	5:27	2:33	DUE TO OVER LOADING OF 500KV NOKHAR.
386	132 KV Hafizabad	CHABBA SANDHWAN	5521	Rural - T/W Dominated		I	8:00	15:49	7:49	FORCE BY RCC
387	132 KV Hafizabad	AHMED PUR	5501	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
388	132 KV Hafizabad	BOEKEY (IRRI)	5506	Rural - T/W Dominated		I	8:00	6:08	1:52	APPROVED PTW
389	132 KV Hafizabad	KOT H.KHAN(TW/3)	5511	Rural - T/W Dominated		I	8:00	3:44	4:16	DUE TO OVER LOADING OF 500KV NOKHAR.
390	132 KV Hafizabad	SAGAR(TW/1)	5512	Rural - T/W Dominated		I	8:00	5:03	2:57	DUE TO OVER LOADING OF 500KV NOKHAR.
391	132 KV Hafizabad	SHAH JAMAL(TW/2)	5510	Rural - T/W Dominated		I	8:00	6:55	1:05	DUE TO OVER LOADING OF 500KV NOKHAR.
392	132 KV Hafizabad	CHAK GHAZI(QADIR)	5514	Rural - T/W Dominated		I	8:00	4:41	3:19	DUE TO OVER LOADING OF 500KV NOKHAR.
393	132 KV Hafizabad	DAHRANWALI(NKR)	5507	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
394	132 KV Hafizabad	LAWERY	5515	Rural - T/W Dominated		I	8:00	3:54	4:06	DUE TO OVER LOADING OF 500KV NOKHAR.
395	132 KV Hafizabad	JAIDKEY	5523	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
396	132 KV Hafizabad	BHOON	5503	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
397	132 KV Hafizabad	PEER KOT(TW/4)	5513	Rural - T/W Dominated		I	8:00	4:52	3:08	DUE TO OVER LOADING OF 500KV NOKHAR.
398	132 KV Qila Didar Singh	N.KOT QAZI	16309	Rural - T/W Dominated		I	8:00	2:23	5:37	DUE TO OVER LOADING OF 500KV NOKHAR.
399	132 KV Qila Didar Singh	NOKHAR	16301	Rural - T/W Dominated		I	8:00	3:49	4:11	BREAK DOWN
400	132 KV Qila Didar Singh	LADHEWALA	16302	Rural - T/W Dominated		I	8:00	4:20	3:40	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
401	132 KV Qila Didar Singh	PUPNAKHA NO.1	16303	Rural - T/W Dominated		I	8:00	3:51	4:09	DUE TO OVER LOADING OF 500KV NOKHAR.
402	132 KV Qila Didar Singh	THABAL DUCHA	16305	Rural - T/W Dominated		I	8:00	3:37	4:23	DUE TO OVER LOADING OF 500KV NOKHAR.
403	132 KV Qila Didar Singh	PHILOKEY	16313	Rural - T/W Dominated		I	8:00	3:12	4:48	DUE TO OVER LOADING OF 500KV NOKHAR.
404	132 KV Qila Didar Singh	KAMOMALHI	16308	Rural - T/W Dominated		I	8:00	5:50	2:10	DUE TO OVER LOADING OF 500KV NOKHAR.
405	132 KV Qila Didar Singh	PUPNAKHA NO.2	16306	Rural - T/W Dominated		I	8:00	3:41	4:19	DUE TO OVER LOADING OF 500KV NOKHAR.
406	132 KV Dinga	AMRA	64404	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
407	132 KV Dinga	JOURA	64402	Rural - T/W Dominated		I	8:00	4:06	3:54	DUE TO OVER LOADING OF 500KV NOKHAR.
408	132 KV Dinga	NOOR JAMAL	64403	Rural - T/W Dominated		I	8:00	4:54	3:06	DUE TO OVER LOADING OF 500KV NOKHAR.
409	132 KV Sukheki	KOT SARWAR	37914	Rural - T/W Dominated		I	8:00	2:49	5:11	BREAK DOWN
410	132 KV Sukheki	SABIT SHAH(H-106)	37904	Rural - T/W Dominated		I	8:00	0:30	7:30	TRIPPING
411	132 KV Sukheki	M.RAHIMA(G.AREA)	37903	Rural - T/W Dominated		I	8:00	0:26	7:34	TRIPPING
412	132 KV Sukheki	UDDOKEY	37911	Rural - T/W Dominated		I	8:00	0:49	7:11	BREAK DOWN
413	132 KV Sukheki	KASSESAY(L-106)	37907	Rural - T/W Dominated		II	8:00	0:31	7:29	BREAK DOWN
414	132 KV Sukheki	JANDOKE(K-106)	37906	Rural - T/W Dominated		I	8:00	0:30	7:30	TRIPPING
415	132 KV Mangowal	PAK WIGAH	62309	Rural - T/W Dominated		I	8:00	5:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
416	132 KV Mangowal	JHUEORWALI	62308	Rural - T/W Dominated		I	8:00	4:14	3:46	DUE TO OVER LOADING OF 500KV NOKHAR.
417	132 KV Mangowal	MONGOWAL-KUNJA	62302	Rural - T/W Dominated		I	8:00	2:13	5:47	DUE TO OVER LOADING OF 500KV NOKHAR.
418	132 KV Mangowal	RANSEEKEY	62307	Rural - T/W Dominated		I	8:00	5:07	2:53	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
419	132 KV Mangowal	LANGAY	62301	Rural - T/W Dominated		I	8:00	4:08	3:52	BREAK DOWN
420	132 KV Mangowal	JOKALIAN	62305	Rural - T/W Dominated		I	8:00	5:42	2:18	DUE TO OVER LOADING OF 500KV NOKHAR.
421	132 KV Mangowal	MACHHIANA	62304	Rural - T/W Dominated		I	8:00	4:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.
422	132 KV Pindi Bhattian	KOT NIZAM	44602	Rural - T/W Dominated		II	8:00	1:09	6:51	BREAK DOWN
423	132 KV Pindi Bhattian	MANI SHORI	44606	Rural - T/W Dominated		I	8:00	0:23	7:37	TRIPPING
424	132 KV Pindi Bhattian	KOT NIKKA	44603	Rural - T/W Dominated		I	8:00	1:09	6:51	BREAK DOWN
425	132 KV Pindi Bhattian	OLD JALAL PUR	44604	Rural - T/W Dominated		I	8:00	0:23	7:37	TRIPPING
426	132 KV Hellan	HELLAN	6211	Rural - T/W Dominated		I	8:00	5:35	2:25	DUE TO OVER LOADING OF 500KV NOKHAR.
427	132 KV Hellan	MURALA	6212	Rural - T/W Dominated		I	8:00	5:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
428	132 KV Hellan	PAHRIAN WALI	6210	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
429	132 KV Hellan	CHHIMAN	6209	Rural - T/W Dominated		I	8:00	7:08	0:52	DUE TO OVER LOADING OF 500KV NOKHAR.
430	132 KV Hellan	JANO CHAK	6214	Rural - T/W Dominated		I	8:00	4:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.
431	132 KV Jalal Pur Bhatian	KHAN PUR	73802	Rural - T/W Dominated		I	8:00	5:05	2:55	DUE TO OVER LOADING OF 500KV NOKHAR.
432	132 KV Jalal Pur Bhatian	KOT MOHABBAT	73805	Rural - T/W Dominated		I	8:00	7:08	0:52	DUE TO OVER LOADING OF 500KV NOKHAR.
433	132 KV Jalal Pur Bhatian	RASULPUR	73806	Rural - T/W Dominated		III	8:00	4:29	3:31	DUE TO OVER LOADING OF 500KV NOKHAR.
434	132 KV Jalal Pur Bhatian	SADOHEY	73812	Rural - T/W Dominated		I	8:00	7:19	0:41	BREAK DOWN
435	132 KV Jalal Pur Bhatian	MEHMOOD PUR	73809	Rural - T/W Dominated		II	8:00	5:46	2:14	BREAK DOWN
436	132 KV Jalal Pur Bhatian	KASSESSAY-2	73811	Rural - T/W Dominated		I	8:00	5:31	2:29	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
437	132 KV Jalal Pur bhatian	KHURRAM CHURERA	73808	Rural - T/W Dominated		I	8:00	5:06	2:54	DUE TO OVER LOADING OF 500KV NOKHAR.
438	132 KV Jalal Pur Bhatian	CHAK BHATTIAN	73801	Rural - T/W Dominated		II	8:00	5:04	2:56	DUE TO OVER LOADING OF 500KV NOKHAR.
439	132 KV New Malakwal	CHOT	32102	Rural - T/W Dominated		I	8:00	5:29	2:31	DUE TO OVER LOADING OF 500KV NOKHAR.
440	132 KV Kolo Tarar	BELO NOW	29904	Rural - T/W Dominated		I	8:00	6:08	1:52	DUE TO OVER LOADING OF 500KV NOKHAR.
441	132 KV Kolo Tarar	KOT CHIAN	29902	Rural - T/W Dominated		I	8:00	4:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
442	132 KV Kolo Tarar	KOLO TARAR	29901	Rural - T/W Dominated		I	8:00	4:23	3:37	DUE TO OVER LOADING OF 500KV NOKHAR.
443	132 KV Kolo Tarar	BERI WALA	29906	Rural - T/W Dominated		I	8:00	6:46	1:14	BREAK DOWN
444	132 KV Kolo Tarar	VANIKE TARAR	29903	Rural - T/W Dominated		I	8:00	4:49	3:11	DUE TO OVER LOADING OF 500KV NOKHAR.
445	132 KV Kolo Tarar	RAHGO SYEDAN	29905	Rural - T/W Dominated		I	8:00	4:12	3:48	DUE TO OVER LOADING OF 500KV NOKHAR.
446	132 KV Kothiala Sheikhan	MIANWAL	8507	Rural - T/W Dominated		I	8:00	4:03	3:57	DUE TO OVER LOADING OF 500KV NOKHAR.
447	132 KV Kothiala Sheikhan	FARRUKH PUR	8515	Rural - T/W Dominated		I	8:00	4:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
448	132 KV Kothiala Sheikhan	SAHNA	8502	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
449	132 KV Kothiala Sheikhan	GOJRA	8514	Rural - T/W Dominated		I	8:00	3:57	4:03	DUE TO OVER LOADING OF 500KV NOKHAR.
450	132 KV Kothiala Sheikhan	DHAKHAY WAL	8516	Rural - T/W Dominated		I	8:00	5:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
451	132 KV Kothiala Sheikhan	MANGAT	8503	Rural - T/W Dominated		I	8:00	5:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
452	132 KV Kothiala Sheikhan	GHOAR	8510	Rural - T/W Dominated		I	8:00	4:35	3:25	DUE TO OVER LOADING OF 500KV NOKHAR.
453	132 KV Kothiala Sheikhan	NAIN	8505	Rural - T/W Dominated		I	8:00	4:48	3:12	DUE TO OVER LOADING OF 500KV NOKHAR.
454	132 KV Kothiala Sheikhan	SAIDA	8506	Rural - T/W Dominated		I	8:00	3:00	5:00	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
455	132 KV Kothiala Sheikhan	QADIRABAD	8513	Rural - T/W Dominated		I	8:00	6:00	2:00	DUE TO OVER LOADING OF 500KV NOKHAR.
456	132 KV Siranwali	TALHARA	37704	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
457	132 KV Siranwali	MACHIKEY	37707	Rural - T/W Dominated		I	8:00	3:50	4:10	DUE TO OVER LOADING OF 500KV NOKHAR.
458	132 KV Siranwali	BASI WALA	37706	Rural - T/W Dominated		I	8:00	5:13	2:47	DUE TO OVER LOADING OF 500KV NOKHAR.
459	132 KV Siranwali	WADALA	37702	Rural - T/W Dominated		I	8:00	3:54	4:06	DUE TO OVER LOADING OF 500KV NOKHAR.
460	132 KV Siranwali	BAIGAY WALI	37705	Rural - T/W Dominated		I	8:00	4:10	3:50	DUE TO OVER LOADING OF 500KV NOKHAR.
461	132 KV Siranwali	MOHANPUR	37703	Rural - T/W Dominated		I	8:00	1:36	6:24	DUE TO OVER LOADING OF 500KV NOKHAR.
462	132 KV Mandi Bahaudin	KOT BALOCH	63201	Rural - T/W Dominated		I	8:00	0:47	7:13	DUE TO OVER LOADING OF 500KV NOKHAR.
463	132 KV Mandi Bahaudin	KHEWA M.B.DIN	63212	Rural - T/W Dominated		I	8:00	3:48	4:12	DUE TO OVER LOADING OF 500KV NOKHAR.
464	132 KV Narowal	SADIQ ABAD	14206	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
465	132 KV Narowal	GHAZI WAL	14211	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
466	132 KV Narowal	DOMALA	14212	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
467	132 KV Narowal	JASSAR	14202	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
468	132 KV Narowal	PAJOWALI	14207	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
469	132 KV Narowal	MONGIAN	14203	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
470	132 KV Narowal	KHAN KHASA	14216	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
471	132 KV Daska Industrial	GLOTIAN	60001	Rural - T/W Dominated		I	8:00	0:00	8:00	RELIEF BY RCC
472	132 KV Daska Industrial	MEETRAN WALI	60005	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
473	132 KV Daska Industrial	SIAN	60007	Rural - T/W Dominated		I	8:00	5:33	2:27	DUE TO OVER LOADING OF 500KV NOKHAR.
474	132 KV Pasrur	BUN BAJWA	34311	Rural - T/W Dominated		I	8:00	6:02	1:58	APPROVED PTW
475	132 KV Pasrur	BADIANA	34301	Rural - T/W Dominated		I	8:00	6:02	1:58	APPROVED PTW
476	132 KV Pasrur	RICHHARA	34312	Rural - T/W Dominated		I	8:00	6:01	1:59	APPROVED PTW
477	132 KV Pasrur	CHAWINDA	34305	Rural - T/W Dominated		I	8:00	3:10	4:50	DUE TO OVER LOADING OF 500KV NOKHAR.
478	132 KV Ghuinki	LADHAR	96902	Rural - T/W Dominated		I	8:00	5:17	2:43	DUE TO OVER LOADING OF 500KV NOKHAR.
479	132 KV Lala Pur	NEW KHANAWALI	82306	Rural - T/W Dominated		I	8:00	5:41	2:19	DUE TO OVER LOADING OF 500KV NOKHAR.
480	132 KV Lala Pur	BHAGOWAL	82307	Rural - T/W Dominated		I	8:00	5:43	2:17	DUE TO OVER LOADING OF 500KV NOKHAR.
481	132 KV Lala Pur	KHANAWALI	82301	Rural - T/W Dominated		I	8:00	3:35	4:25	DUE TO OVER LOADING OF 500KV NOKHAR.
482	132 KV Daska City	M.R.LINK	26307	Rural - T/W Dominated		I	8:00	4:15	3:45	DUE TO OVER LOADING OF 500KV NOKHAR.
483	132 KV Daska City	K.KEY	26306	Rural - T/W Dominated		I	8:00	5:18	2:42	DUE TO OVER LOADING OF 500KV NOKHAR.
484	132 KV Pasrur Road Sialkot	VARIO	20116	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
485	132 KV Pasrur Road Sialkot	GOPAL PUR	20118	Rural - T/W Dominated		I	8:00	2:59	5:01	BREAK DOWN
486	132 KV Pasrur Road Sialkot	GUNNA	20107	Rural - T/W Dominated		I	8:00	2:37	5:23	DUE TO OVER LOADING OF 500KV NOKHAR.
487	132 KV Sialkot Cantt	SHADIWAL	51110	Rural - T/W Dominated		I	8:00	2:58	5:02	DUE TO OVER LOADING OF 500KV NOKHAR.
488	132 KV Sambrial	JAMKE	18702	Rural - T/W Dominated		I	8:00	4:50	3:10	DUE TO OVER LOADING OF 500KV NOKHAR.
489	132 KV Sambrial	MAJRA	18704	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
490	132 KV Sambrial	KOT DINA	18703	Rural - T/W Dominated		I	8:00	6:45	1:15	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
491	220 KV Ghakkhar - 220 kV	KOT NOORA	4405	Rural - T/W Dominated		I	8:00	6:43	1:17	DUE TO OVER LOADING OF 500KV NOKHAR.
492	220 KV Ghakkhar - 220 kV	BADDOKI	4401	Rural - T/W Dominated		I	8:00	5:17	2:43	DUE TO OVER LOADING OF 500KV NOKHAR.
493	220 KV Ghakkhar - 220 kV	JALAL	4412	Rural - T/W Dominated		I	8:00	4:38	3:22	DUE TO OVER LOADING OF 500KV NOKHAR.
494	220 KV Ghakkhar - 220 kV	FATEH GARH N	4415	Rural - T/W Dominated		I	8:00	4:46	3:14	DUE TO OVER LOADING OF 500KV NOKHAR.
495	220 KV Ghakkhar - 220 kV	GILL WALA	4403	Rural - T/W Dominated		I	8:00	6:54	1:06	DUE TO OVER LOADING OF 500KV NOKHAR.
496	220 KV Ghakkhar - 220 kV	AHMED NAGAR	4418	Rural - T/W Dominated		I	8:00	5:26	2:34	DUE TO OVER LOADING OF 500KV NOKHAR.
497	220 KV Ghakkhar - 220 kV	T.K. WALI	4411	Rural - T/W Dominated		I	8:00	3:00	5:00	DUE TO OVER LOADING OF 500KV NOKHAR.
498	132 KV Ratti Gujrat	MIAN M.PANAH	108103	Rural - T/W Dominated		I	8:00	2:59	5:01	DUE TO OVER LOADING OF 500KV NOKHAR.
499	132 KV Phalia	LUK	108006	Rural - T/W Dominated		I	8:00	1:34	6:26	DUE TO OVER LOADING OF 500KV NOKHAR.
500	132 KV Phalia	DHAREIKAN	108007	Rural - T/W Dominated		I	8:00	2:01	5:59	EMERGENCY PTW
501	132 KV Hafiz Abad-II	SAKHI	108606	Rural - T/W Dominated		I	8:00	6:46	1:14	DUE TO OVER LOADING OF 500KV NOKHAR.
502	132 KV Hafiz Abad-II	KOT MIAN	108605	Rural - T/W Dominated		I	8:00	6:47	1:13	DUE TO OVER LOADING OF 500KV NOKHAR.
503	132 KV Hafiz Abad-II	KOT MUBARIK	108602	Rural - T/W Dominated		I	8:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
504	132 KV Hafiz Abad-II	JAGGAN WALA	108604	Rural - T/W Dominated		I	8:00	5:40	2:20	DUE TO OVER LOADING OF 500KV NOKHAR.
505	132 KV Daska New	MALIANWALA	110207	Rural - T/W Dominated		I	8:00	4:12	3:48	BREAK DOWN
506	132 KV Daska New	GOJRA	110202	Rural - T/W Dominated		I	8:00	4:44	3:16	DUE TO OVER LOADING OF 500KV NOKHAR.
507	132 KV Daska New	ADAMKEY	110205	Rural - T/W Dominated		I	8:00	3:56	4:04	DUE TO OVER LOADING OF 500KV NOKHAR.
508	132 KV Daska New	WAZIRABAD ROAD	110203	Rural - T/W Dominated		I	8:00	4:56	3:04	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
509	132 KV Daska New	SUKHAR NEHER	110206	Rural - T/W Dominated		I	8:00	5:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
510	132 KV Shaheen Abad GRW	GUJRANWALA-1	5007	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
511	132 KV Shaheen Abad GRW	DAL BAZAR	5034	Commercial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
512	132 KV Shaheen Abad GRW	GUJRANWALA-2	5008	Commercial Dominated		I	4:00	1:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
513	132 KV College Road GRW	IRON STEEL SHEET MARKET	3233	Commercial Dominated		I	4:00	0:26	3:34	DUE TO OVER LOADING OF 500KV NOKHAR.
514	132 KV Hafiz Abad Road GRW	FRUIT MANDI	81401	Commercial Dominated		I	4:00	1:34	2:26	DUE TO OVER LOADING OF 500KV NOKHAR.
515	132 KV Cantt. GRW	FAZAL CENTER	95424	Commercial Dominated		I	4:00	1:20	2:40	DUE TO OVER LOADING OF 500KV NOKHAR.
516	132 KV Lahore Road GRW	NAAFEH TOWER	72525	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
517	132 KV Pasrur Road GRW	NEW SATELLITE TOWN	15717	Commercial Dominated		I	4:00	1:09	2:51	DUE TO OVER LOADING OF 500KV NOKHAR.
518	132 KV Pasrur Road GRW	D.N.ROAD	15701	Commercial Dominated		I	4:00	1:23	2:37	DUE TO OVER LOADING OF 500KV NOKHAR.
519	132 KV Theri Sansi	KASHMIR ROAD	21417	Commercial Dominated		I	4:00	1:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
520	132 KV Wazirabad	WAZIR ABAD	22210	Commercial Dominated		I	4:00	2:07	1:53	DUE TO OVER LOADING OF 500KV NOKHAR.
521	132 KV Gujrat-I	FURNITUR MARKET	5116	Commercial Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
522	132 KV Kharian	MAIN BAZAR	10711	Commercial Dominated		I	4:00	2:56	1:04	DUE TO OVER LOADING OF 500KV NOKHAR.
523	132 KV Kharian	KHARIAN CITY	10701	Commercial Dominated		I	4:00	3:00	1:00	DUE TO OVER LOADING OF 500KV NOKHAR.
524	132 KV Gujrat-II	COURT ROAD	46905	Commercial Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
525	132 KV Gujrat-II	JINNAH ROAD	46904	Commercial Dominated		I	4:00	1:58	2:02	DUE TO OVER LOADING OF 500KV NOKHAR.
526	132 KV Gujrat-II	MUSLIM BAZAR	46903	Commercial Dominated		I	4:00	2:11	1:49	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
527	132 KV Gujrat-II	MARGHZAR	46906	Commercial Dominated		I	4:00	2:55	1:05	DUE TO OVER LOADING OF 500KV NOKHAR.
528	132 KV Lala Musa	LALA MUSA CITY	11603	Commercial Dominated		I	4:00	3:35	0:25	DUE TO OVER LOADING OF 500KV NOKHAR.
529	132 KV Lala Musa	MAIN BAZAR LALAMUSA	11613	Commercial Dominated		I	4:00	3:21	0:39	BREAK DOWN
530	132 KV Nowshera Virkan	NEW NOWSHERA VIRKAN	28012	Commercial Dominated		I	4:00	2:01	1:59	DUE TO OVER LOADING OF 500KV NOKHAR.
531	132 KV Nowshera Virkan	N.VIRKAN	28002	Commercial Dominated		I	4:00	2:01	1:59	DUE TO OVER LOADING OF 500KV NOKHAR.
532	132 KV Hafizabad	MAKKAH TOWN	5520	Commercial Dominated		I	4:00	4:28	0:28	FORCE BY RCC
533	132 KV Hafizabad	HUSSAIN PURA	5516	Commercial Dominated		I	4:00	15:49	11:49	FORCE BY RCC
534	132 KV Qila Didar Singh	MAIN BAZAR Q.D.SINGH	16310	Commercial Dominated		I	4:00	2:56	1:04	DUE TO OVER LOADING OF 500KV NOKHAR.
535	132 KV New Malakwal	MALAKWAL.CITY	32103	Commercial Dominated		I	4:00	3:25	0:35	DUE TO OVER LOADING OF 500KV NOKHAR.
536	132 KV Kothiala Sheikhan	PHALIA-II	8509	Commercial Dominated		I	4:00	3:40	0:20	DUE TO OVER LOADING OF 500KV NOKHAR.
537	132 KV Kothiala Sheikhan	COLLEGE RD.PHALIA	8512	Commercial Dominated		I	4:00	4:00	0:00	DUE TO OVER LOADING OF 500KV NOKHAR.
538	132 KV Mandi Bahaudin	PHALIA ROAD M.B.D	63208	Commercial Dominated		I	4:00	2:34	1:26	BREAK DOWN
539	132 KV Mandi Bahaudin	M.B. DIN CITY	63203	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
540	132 KV Mandi Bahaudin	KATCHERY ROAD M.B.DIN	63211	Commercial Dominated		I	4:00	3:11	0:49	DUE TO OVER LOADING OF 500KV NOKHAR.
541	132 KV Mandi Bahaudin	CRYSTAL	63214	Commercial Dominated		I	4:00	3:12	0:48	APPROVED PTW
542	132 KV Narowal	CIVIL LINE	14209	Commercial Dominated		I	4:00	0:21	3:39	TRIPPING
543	132 KV Narowal	NAROWAL	14204	Commercial Dominated		I	4:00	0:04	3:56	TRIPPING
544	132 KV Pasrur	PASRUR	34303	Commercial Dominated		I	4:00	6:07	2:07	APPROVED PTW

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
545	132 KV Pasrur	PASRUR NO-2	34307	Commercial Dominated		I	4:00	3:16	0:44	DUE TO OVER LOADING OF 500KV NOKHAR.
546	132 KV Shakhar Garh	CITY-I(Shakhar Garh)	80204	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
547	132 KV Shakhar Garh	CITY-II(Shakhar Garh)	80201	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
548	132 KV Pasrur Road Sialkot	CIRCULIR ROAD	20101	Commercial Dominated		I	4:00	1:12	2:48	DUE TO OVER LOADING OF 500KV NOKHAR.
549	132 KV Zafarwal	ZAFARWAL	40503	Commercial Dominated		I	4:00	4:06	0:06	BREAK DOWN
550	132 KV Sialkot City	MAIN BAZAR	37516	Commercial Dominated		I	4:00	1:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
551	132 KV Sialkot New	ABBOT ROAD	44402	Commercial Dominated		I	4:00	1:03	2:57	DUE TO OVER LOADING OF 500KV NOKHAR.
552	132 KV Sialkot Cantt	GHAZI PUR	51117	Commercial Dominated		I	4:00	1:12	2:48	BREAK DOWN
553	132 KV Sialkot Cantt	RAILWAY ROAD	51101	Commercial Dominated		I	4:00	1:11	2:49	DUE TO OVER LOADING OF 500KV NOKHAR.
554	132 KV Sialkot Cantt	MUHAMMAD PURA	51102	Commercial Dominated		I	4:00	2:16	1:44	DUE TO OVER LOADING OF 500KV NOKHAR.
555	132 KV Sambrial	SAMBRIAL-1	18705	Commercial Dominated		I	4:00	4:59	0:59	FORCE BY RCC
556	132 KV Sambrial	SAMBRIAL-2	18707	Commercial Dominated		I	4:00	13:52	9:52	FORCE BY RCC
557	132 KV Phalia	MAIN BAZAR	108004	Commercial Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
558	132 KV Hafiz Abad-II	FAROOQ-E-AZAM ROAD	108607	Commercial Dominated		I	4:00	4:27	0:27	FORCE BY RCC
559	132 KV Hafiz Abad-II	MUGHAL PURA	108603	Commercial Dominated		I	4:00	5:26	1:26	FORCE BY RCC
560	132 KV OPH Sialkot	FORT	109402	Commercial Dominated		I	4:00	1:26	2:34	DUE TO OVER LOADING OF 500KV NOKHAR.
561	132 KV OPH Sialkot	TEHSIL BAZAR	109401	Commercial Dominated		I	4:00	1:26	2:34	DUE TO OVER LOADING OF 500KV NOKHAR.
562	132 KV OPH Sialkot	GREEN WOOD STREET	109403	Commercial Dominated		I	4:00	1:16	2:44	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
563	132 KV Sheranwala Bagh	SHERANWALA BAGH	111901	Commercial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
564	132 KV Sheranwala Bagh	SIALKOTI GATE	111909	Commercial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
565	132 KV Khialy GRW	NEW FRUIT MANDI	112203	Commercial Dominated		I	4:00	1:21	2:39	DUE TO OVER LOADING OF 500KV NOKHAR.
566	132 KV Khialy GRW	IFTEKHAR COLONY	112202	Commercial Dominated		I	4:00	1:29	2:31	DUE TO OVER LOADING OF 500KV NOKHAR.
567	132 KV Shaheen Abad GRW	GEPCO FEEDER	5041	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
568	132 KV Shaheen Abad GRW	GULSHAN IQBAL	5023	Industrial Dominated		I	4:00	0:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
569	132 KV Shaheen Abad GRW	DHULLAY NEW	5036	Industrial Dominated		I	4:00	0:57	3:03	DUE TO OVER LOADING OF 500KV NOKHAR.
570	132 KV Shaheen Abad GRW	KASHMIR ROAD	5033	Industrial Dominated		I	4:00	1:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
571	132 KV Shaheen Abad GRW	S.I.E.NO-2	5013	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
572	132 KV Shaheen Abad GRW	S.I.E.NO-1	5014	Industrial Dominated		I	4:00	1:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
573	132 KV Shaheen Abad GRW	CLIMAXABAD	5027	Industrial Dominated		I	4:00	0:20	3:40	TRIPPING
574	132 KV College Road GRW	BY PASS ROAD	3202	Industrial Dominated		I	4:00	2:10	1:50	DUE TO OVER LOADING OF 500KV NOKHAR.
575	132 KV College Road GRW	BILAL ROAD	3217	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
576	132 KV College Road GRW	RAJ KOT	3235	Industrial Dominated		I	4:00	2:15	1:45	DUE TO OVER LOADING OF 500KV NOKHAR.
577	132 KV College Road GRW	FAROOQ GUNJ	3203	Industrial Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
578	132 KV Hafiz Abad Road GRW	DARBAR QADRIA	81404	Industrial Dominated		I	4:00	0:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
579	132 KV Hafiz Abad Road GRW	MADNI ROAD	81419	Industrial Dominated		I	4:00	0:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
580	132 KV Hafiz Abad Road GRW	NOSHERA ROAD	81415	Industrial Dominated		I	4:00	0:33	3:27	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
581	132 KV Hafiz Abad Road GRW	MUBRAK SHAH	81412	Industrial Dominated		I	4:00	1:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
582	132 KV Hafiz Abad Road GRW	MUHAMMAD NAGAR	81403	Industrial Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
583	132 KV Hafiz Abad Road GRW	JINNAH ROAD	81414	Industrial Dominated		I	4:00	0:57	3:03	DUE TO OVER LOADING OF 500KV NOKHAR.
584	132 KV Hafiz Abad Road GRW	GUL BARK COLONY	81424	Industrial Dominated		I	4:00	0:33	3:27	DUE TO OVER LOADING OF 500KV NOKHAR.
585	132 KV Cantt. GRW	FOREST COLONY	95406	Industrial Dominated		I	4:00	2:04	1:56	DUE TO OVER LOADING OF 500KV NOKHAR.
586	132 KV Cantt. GRW	INCOME TAX COLONY	95404	Industrial Dominated		I	4:00	2:18	1:42	DUE TO OVER LOADING OF 500KV NOKHAR.
587	132 KV Lahore Road GRW	MUKHTAR COLONY	72510	Industrial Dominated		I	4:00	1:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
588	132 KV Lahore Road GRW	JALIL TOWN	72509	Industrial Dominated		I	4:00	0:24	3:36	DUE TO OVER LOADING OF 500KV NOKHAR.
589	132 KV Lahore Road GRW	KASHMIR COLONY	72504	Industrial Dominated		I	4:00	0:19	3:41	TRIPPING
590	132 KV Lahore Road GRW	INDUSTRIAL-3	72519	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
591	132 KV Pasrur Road GRW	COLONY(015725)	15725	Industrial Dominated		I	4:00	0:31	3:29	DUE TO OVER LOADING OF 500KV NOKHAR.
592	132 KV Theri Sansi	KATCHA EMINABAD ROAD	21419	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
593	132 KV Theri Sansi	BAJWA ROAD 2	21420	Industrial Dominated		I	4:00	0:23	3:37	TRIPPING
594	132 KV Theri Sansi	JAMIA MUHAMMADIA	21408	Industrial Dominated		I	4:00	0:22	3:38	TRIPPING
595	132 KV Theri Sansi	GALA KOSAR FAN WALA	21423	Industrial Dominated		I	4:00	0:21	3:39	TRIPPING
596	132 KV Theri Sansi	G.T.ROAD-1(T- SANSI)	21403	Industrial Dominated		I	4:00	3:38	0:22	BREAK DOWN
597	132 KV Theri Sansi	BOKHARI COLONY	21415	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
598	132 KV Theri Sansi	SANAT ROAD FEEDER	21418	Industrial Dominated		I	4:00	0:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
599	132 KV Theri Sansi	KHURSHID ALAM	21421	Industrial Dominated		I	4:00	0:23	3:37	TRIPPING
600	132 KV Theri Sansi	GALA THREE STAR WALA	21416	Industrial Dominated		I	4:00	0:46	3:14	DUE TO OVER LOADING OF 500KV NOKHAR.
601	132 KV Wazirabad	P.N.P	22206	Industrial Dominated		I	4:00	1:53	2:07	LOAD REDUCED
602	132 KV Gujrat-I	SHEIKH PUR	5109	Industrial Dominated		I	4:00	1:51	2:09	DUE TO OVER LOADING OF 500KV NOKHAR.
603	132 KV Gujrat-I	NAGRANWALA	5107	Industrial Dominated		I	4:00	0:55	3:05	DUE TO OVER LOADING OF 500KV NOKHAR.
604	132 KV Gujrat-I	HAYAT PURA	5108	Industrial Dominated		I	4:00	1:39	2:21	DUE TO OVER LOADING OF 500KV NOKHAR.
605	132 KV Aroop GRW	SARDAR TOWN	97405	Industrial Dominated		I	4:00	1:00	3:00	DUE TO OVER LOADING OF 500KV NOKHAR.
606	132 KV Kamoke	SALAR	9415	Industrial Dominated		I	4:00	0:05	3:55	TRIPPING
607	132 KV Kamoke	C.WALI (P.STEEL)	9412	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
608	132 KV Jalal Pur Bhatian	JALAL PUR CITY	73803	Industrial Dominated		II	4:00	2:30	1:30	BREAK DOWN
609	132 KV Narowal	INDUSTRIAL(NAROWAL)	14208	Industrial Dominated		I	4:00	0:58	3:02	BREAK DOWN
610	132 KV Daska Industrial	APPLO	60003	Industrial Dominated		I	4:00	1:58	2:02	DUE TO OVER LOADING OF 500KV NOKHAR.
611	132 KV Daska Industrial	O.K.	60004	Industrial Dominated		I	4:00	1:52	2:08	DUE TO OVER LOADING OF 500KV NOKHAR.
612	132 KV Ghuinki	GHUNIKI (IND-EXP-2)	96903	Industrial Dominated		I	4:00	2:27	1:33	DUE TO OVER LOADING OF 500KV NOKHAR.
613	132 KV Ghuinki	IND-EXP-3	96906	Industrial Dominated		I	4:00	2:26	1:34	DUE TO OVER LOADING OF 500KV NOKHAR.
614	132 KV Ghuinki	IMAM BUKHARI	96908	Industrial Dominated		I	4:00	2:32	1:28	DUE TO OVER LOADING OF 500KV NOKHAR.
615	132 KV Pasrur Road Sialkot	BUDIANA EXPRESS	20111	Industrial Dominated		I	4:00	1:27	2:33	DUE TO OVER LOADING OF 500KV NOKHAR.
616	132 KV Sialkot City	IND-EXPRESS-1	37524	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
617	132 KV Sialkot New	ADALAT GHARH	44417	Industrial Dominated		I	4:00	2:44	1:16	BREAK DOWN
618	220 KV Ghakkhar - 220 kv	SUGAR MILL	4420	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
619	220 KV Sahawal Sialkot-220kv	HAZARAT MEHBOOB-E-ZAT	81303	Industrial Dominated		I	4:00	4:59	0:59	DUE TO OVER LOADING OF 500KV NOKHAR.
620	132 KV Ratti Gujrat	SHAHEEN	108107	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
621	132 KV Ratti Gujrat	GHAURI	108102	Industrial Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
622	132 KV Chianwali	BE-NAZIR ROAD	108204	Industrial Dominated		I	4:00	0:16	3:44	TRIPPING
623	132 KV Chianwali	INDUSTRIAL WEST	108202	Industrial Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
624	132 KV OPH Sialkot	HAJI PURA	109404	Industrial Dominated		I	4:00	0:24	3:36	TRIPPING
625	132 KV Daska New	COLLEGE ROAD	110201	Industrial Dominated		I	4:00	2:03	1:57	DUE TO OVER LOADING OF 500KV NOKHAR.
626	132 KV Daska New	NEW APPALO	110208	Industrial Dominated		I	4:00	2:14	1:46	EMERGENCY PTW
627	132 KV Sheranwala Bagh	INDUSTRIAL EAST	111907	Industrial Dominated		I	4:00	1:27	2:33	DUE TO OVER LOADING OF 500KV NOKHAR.
628	132 KV Sheranwala Bagh	MIAN SANSI ROAD	111905	Industrial Dominated		I	4:00	0:50	3:10	DUE TO OVER LOADING OF 500KV NOKHAR.
629	132 KV Sheranwala Bagh	BAKER MANDI	111903	Industrial Dominated		I	4:00	1:22	2:38	DUE TO OVER LOADING OF 500KV NOKHAR.
630	132 KV Sheranwala Bagh	BAJWA ROAD	111906	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
631	132 KV Sheranwala Bagh	HIGHWAY COLONY	111908	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
632	132 KV Sheranwala Bagh	UMAR FAROOQ ROAD	111910	Industrial Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
633	132 KV Khialy GRW	NEW DATA GUNJ BUX	112204	Industrial Dominated		I	4:00	0:31	3:29	DUE TO OVER LOADING OF 500KV NOKHAR.
634	132 KV College Road GRW	PRINCE ROAD	3223	Power Loom Dominated		I	4:00	2:19	1:41	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
635	132 KV College Road GRW	JAMIA ASHRAFIA	3224	Power Loom Dominated		I	4:00	1:22	2:38	DUE TO OVER LOADING OF 500KV NOKHAR.
636	132 KV College Road GRW	HAFIZABAD RD	3204	Power Loom Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
637	132 KV College Road GRW	MAKKAH ROAD		Power Loom Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
638	132 KV College Road GRW	MUSLIM TOWN	3207	Power Loom Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
639	132 KV Pasrur Road GRW	J.B.WALA	15703	Power Loom Dominated		I	4:00	5:22	1:22	BREAK DOWN
640	132 KV Pasrur Road GRW	PONDAWALA	15729	Power Loom Dominated		I	4:00	0:29	3:31	TRIPPING
641	132 KV Pasrur Road GRW	NEW FARID TOWN	15712	Power Loom Dominated		I	4:00	1:01	2:59	DUE TO OVER LOADING OF 500KV NOKHAR.
642	132 KV Pasrur Road GRW	RACE COURSE ROAD	15731	Power Loom Dominated		I	4:00	0:19	3:41	TRIPPING
643	132 KV Pasrur Road GRW	FARID TOWN	15705	Power Loom Dominated		I	4:00	0:47	3:13	DUE TO OVER LOADING OF 500KV NOKHAR.
644	132 KV Pasrur Road GRW	CHAMANSHAH	15707	Power Loom Dominated		I	4:00	1:29	2:31	DUE TO OVER LOADING OF 500KV NOKHAR.
645	132 KV Pasrur Road GRW	CHAMRA MANDI	15730	Power Loom Dominated		I	4:00	1:22	2:38	DUE TO OVER LOADING OF 500KV NOKHAR.
646	132 KV Pasrur Road GRW	SALEEM COLONY	15710	Power Loom Dominated		I	4:00	2:05	1:55	DUE TO OVER LOADING OF 500KV NOKHAR.
647	132 KV Theri Sansi	SHEIKHUPURA ROAD	21407	Power Loom Dominated		I	4:00	0:59	3:01	DUE TO OVER LOADING OF 500KV NOKHAR.
648	132 KV Kamoke	KAMOKEY-2	9409	Power Loom Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
649	132 KV Kamoke	KAMOKE-5	9423	Power Loom Dominated		I	4:00	0:37	3:23	BREAK DOWN
650	132 KV Kamoke	SALAMAT PURA	9416	Power Loom Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
651	132 KV Kamoke	KAMOKEY-3	9402	Power Loom Dominated		I	4:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
652	132 KV Kamoke	KAMOKEY 4	9422	Power Loom Dominated		I	4:00	0:00	4:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
653	132 KV Kamoke	KAMOKEY-1	9404	Power Loom Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
654	132 KV Kamoke	MASTER TILES	9418	Power Loom Dominated		I	4:00	0:00	4:00	RELIEF BY RCC
655	132 KV Jalal Pur Jattan	ISLAM GARH	6702	Power Loom Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
656	132 KV Jalal Pur Jattan	ABDUL SATTAR EIDHI	6714	Power Loom Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
657	132 KV Jalal Pur Jattan	MAIN BAZAR	6704	Power Loom Dominated		I	4:00	2:58	1:02	DUE TO OVER LOADING OF 500KV NOKHAR.
658	132 KV Jalal Pur Jattan	SHABIR SHARIF SHAHEED	6710	Power Loom Dominated		I	4:00	1:57	2:03	DUE TO OVER LOADING OF 500KV NOKHAR.
659	132 KV Hafiz Abad-II	RAJA CHOWK	108608	Power Loom Dominated		I	4:00	3:34	0:26	DUE TO OVER LOADING OF 500KV NOKHAR.
660	132 KV Shaheen Abad GRW	BOSS(005043)	5043	Independent Industry (B3)		I	0:00	7:31	7:31	NO-NOMINAL LOAD
661	132 KV Shaheen Abad GRW	S.I.E.3	5028	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
662	132 KV College Road GRW	SHAHEEN GATTA MILLS	3232	Independent Industry (B3)		I	0:00	0:22	0:22	TRIPPING
663	132 KV College Road GRW	KHALID MEHMOOD PRESS STEEL RE-RUL	3234	Independent Industry (B3)		I	0:00	6:27	6:27	NO-NOMINAL LOAD
664	132 KV Hafiz Abad Road GRW	FRIENDS PAPER MILLS	81421	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
665	132 KV Lahore Road GRW	SUPER ASIA	72521	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
666	132 KV Lahore Road GRW	PEPSI COLA	72514	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
667	132 KV Theri Sansi	CITIZEN(021422)	21422	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
668	132 KV Gujrat-I	SERVICE	5111	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
669	132 KV Gujrat-II	STATE LIFE	46911	Independent Industry (B3)		I	0:00	8:14	8:14	NO-NOMINAL LOAD
670	132 KV Kamoke	NEW ALLUSYS	9420	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
671	132 KV Kamoke	KAMOKE PAPER AND BOARD MILLS	9421	Independent Industry (B3)		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
672	132 KV Kamoke	H.H. PAPER MILLS	9426	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
673	132 KV Eminabad	AL MARWA FEED INDUSTRY	50926	Independent Industry (B3)		I	0:00	7:01	7:01	NO-NOMINAL LOAD
674	132 KV Eminabad	FIVE STAR FEED MILLS	50924	Independent Industry (B3)		I	0:00	Comm. Issue	#VALUE!	APPROVED PTW
675	132 KV Qila Didar Singh	AL HAMMAD BOARD MILL	16315	Independent Industry (B3)		I	0:00	0:13	0:13	TRIPPING
676	132 KV Sukheki	NISHAT DAIRY	37913	Independent Industry (B3)		I	0:00	0:23	0:23	FORCE BY RCC
677	132 KV Mangowal	FARUKI PULP	62310	Independent Industry (B3)		I	0:00	0:20	0:20	TRIPPING
678	132 KV Jalal Pur Bhatian	MAZCO	73810	Independent Industry (B3)		I	0:00	0:30	0:30	FORCE BY RCC
679	220 KV Ghakkhar - 220 kV	OLD GHAKKAR	4402	Independent Industry (B3)		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
680	220 KV Ghakkhar - 220 kV	N.L.C(004406)	4406	Independent Industry (B3)		I	0:00	1:00	1:00	NO-NOMINAL LOAD
681	132 KV Khialy GRW	COCA COLA	112207	Independent Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
682	132 KV Cantt. GRW	SONICA INDUSTRY	95421	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
683	132 KV Wazirabad	DARSON	22220	Cont. Process Industry (B3)		I	0:00	0:16	0:16	TRIPPING
684	132 KV FatehPur	CHENAB BOARD	27311	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
685	132 KV Gujrat-II	NEW SERVICE	46907	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
686	132 KV Kamoke	SONEX TILES	9419	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
687	220 KV Ghakkhar - 220 kV	MAIZE	4413	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC
688	132 KV Chianwali	NEW MASTER TILE	108208	Cont. Process Industry (B3)		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
689	132 KV Kamoke	TARIQ SPINNING MILLS	9424	Independent Textile		I	0:00	0:56	0:56	NO-NOMINAL LOAD
690	132 KV Kamoke	KHALID NAZIR	9414	Independent Textile		I	0:00	0:00	0:00	RELIEF BY RCC
691	132 KV Eminabad	KH. SPINN MILL	50912	Independent Textile		I	0:00	8:08	8:08	APPROVED PTW
692	132 KV Sukheki	CRESCENT BAHUMAN	37912	Independent Textile		I	0:00	0:47	0:47	FORCE BY RCC
693	132 KV Mangowal	KUNJAH T/MILL	62303	Independent Textile		I	0:00	0:00	0:00	RELIEF BY RCC
694	132 KV Kothiala Sheikhan	MALKWAL.T.MILL	8508	Independent Textile		I	0:00	0:00	0:00	RELIEF BY RCC
695	132 KV Chianwali	AL-HARAM TEXTILE	108207	Independent Textile		I	0:00	0:00	0:00	RELIEF BY RCC
696	132 KV Lahore Road GRW	INDUSTRIAL-2(072507)	72507	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
697	132 KV Lahore Road GRW	REGAL CHINA	72503	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
698	132 KV Lahore Road GRW	CERAMICS II	72522	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
699	132 KV Lahore Road GRW	KHIALI-2	72508	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
700	132 KV Lahore Road GRW	INDUSTRIAL-4	72524	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
701	132 KV Kamoke	JUBLI PAPER MILL	9411	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
702	132 KV Jalal Pur Bhatian	INDUSTRIAL(JALAL PUR)	73804	Industrial Estate & Cluster		I	0:00	0:17	0:17	TRIPPING
703	132 KV Daska Industrial	S.I.E.	60002	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
704	132 KV Sialkot City	EXCHANGE (SIE-2)	37519	Industrial Estate & Cluster		I	0:00	0:59	0:59	DUE TO OVER LOADING OF 500KV NOKHAR.
705	132 KV Sialkot City	INDUSTRIAL (SIE-1)	37523	Industrial Estate & Cluster		I	0:00	0:59	0:59	DUE TO OVER LOADING OF 500KV NOKHAR.
706	132 KV Ratti Gujrat	S I E	108106	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
707	132 KV Ratti Gujrat	G T ROAD(RATTI GUJRAT)	108105	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
708	132 KV Chianwali	NEW JUBLEE	108209	Industrial Estate & Cluster		I	0:00	0:04	0:04	TRIPPING
709	132 KV Chianwali	INDUSTRIAL EAST	108201	Industrial Estate & Cluster		I	0:00	0:00	0:00	RELIEF BY RCC
710	132 KV Shaheen Abad GRW	FURNACE NO.3	5025	Independent/Furnace		I	0:00	0:25	0:25	NO-NOMINAL LOAD
711	132 KV Shaheen Abad GRW	BISMILLAH STEEL	5042	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
712	132 KV Shaheen Abad GRW	L.D STEEL	5030	Independent/Furnace		I	0:00	16:52	16:52	NO-NOMINAL LOAD
713	132 KV Shaheen Abad GRW	FURNACE NO.1	5021	Independent/Furnace		I	0:00	10:54	10:54	NO-NOMINAL LOAD
714	132 KV Shaheen Abad GRW	SUPRA STEEL MILL	5038	Independent/Furnace		I	0:00	7:18	7:18	NO-NOMINAL LOAD
715	132 KV Shaheen Abad GRW	FURNACE NO.4	5026	Independent/Furnace		I	0:00	9:24	9:24	NO-NOMINAL LOAD
716	132 KV Shaheen Abad GRW	INDUSTRIAL(SHN.ABAD)	5002	Independent/Furnace		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
717	132 KV College Road GRW	MILLER STEEL	3216	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
718	132 KV College Road GRW	GRW.S.CASTING	3226	Independent/Furnace		I	0:00	8:43	8:43	NO-NOMINAL LOAD
719	132 KV College Road GRW	RAUF STEEL	3225	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
720	132 KV College Road GRW	S.S.MILLS	3215	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
721	132 KV College Road GRW	GHAZI(003218)	3218	Independent/Furnace		I	0:00	1:20	1:20	NO-NOMINAL LOAD
722	132 KV College Road GRW	ISHAQ STEEL	3222	Independent/Furnace		I	0:00	8:43	8:43	NO-NOMINAL LOAD
723	132 KV Hafiz Abad Road GRW	IMS MILLS	81422	Independent/Furnace		I	0:00	0:06	0:06	TRIPPING
724	132 KV Hafiz Abad Road GRW	MADINA STEEL MILLS	81410	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
725	132 KV Hafiz Abad Road GRW	HAQ BAHU STEEL	81417	Independent/Furnace		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
726	132 KV Hafiz Abad Road GRW	HAMID FURNACE	81418	Independent/Furnace		I	0:00	3:42	3:42	NO-NOMINAL LOAD
727	132 KV Hafiz Abad Road GRW	MAKHAH STEEL	81411	Independent/Furnace		I	0:00	3:39	3:39	NO-NOMINAL LOAD
728	132 KV Cantt. GRW	ASHRAF STEEL	95415	Independent/Furnace		I	0:00	9:58	9:58	NO-NOMINAL LOAD
729	132 KV Cantt. GRW	F-8	95408	Independent/Furnace		I	0:00	8:34	8:34	NO-NOMINAL LOAD
730	132 KV Cantt. GRW	IRFAN SIDDIQUE RE-ROLLING MILL	95420	Independent/Furnace		I	0:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
731	132 KV Cantt. GRW	SHAHZAD STEEL FURNACE	95417	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
732	132 KV Cantt. GRW	KHALID ASHRAF STEEL	95419	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
733	132 KV Cantt. GRW	RAWAHA STEEL	95425	Independent/Furnace		I	0:00	15:24	15:24	NO-NOMINAL LOAD
734	132 KV Cantt. GRW	F-2	95407	Independent/Furnace		I	0:00	0:53	0:53	NO-NOMINAL LOAD
735	132 KV Lahore Road GRW	AL-KARAM STEEL MILL	72513	Independent/Furnace		I	0:00	3:22	3:22	NO-NOMINAL LOAD
736	132 KV Lahore Road GRW	S.I.E. NO. 2	72505	Independent/Furnace		I	0:00	9:02	9:02	NO-NOMINAL LOAD
737	132 KV Lahore Road GRW	KHALID ILYAS STEEL	72512	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
738	132 KV Lahore Road GRW	ISLAMABAD STEEL	72511	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
739	132 KV Theri Sansi	FURNANCE	21412	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
740	132 KV Aroop GRW	F-6	97407	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
741	132 KV Aroop GRW	FAROOQ STEEL	97408	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
742	132 KV Aroop GRW	F-5	97406	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
743	132 KV Aroop GRW	TAJ STEEL	97409	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
744	132 KV Aroop GRW	WAQAS STEEL	97415	Independent/Furnace		I	0:00	9:06	9:06	NO-NOMINAL LOAD
745	132 KV Aroop GRW	ASIF STEEL	97411	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
746	132 KV Aroop GRW	NADEEM STEEL	97414	Independent/Furnace		I	0:00	3:43	3:43	NO-NOMINAL LOAD
747	132 KV Aroop GRW	F-7	97404	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
748	132 KV Eminabad	RAJPUT STEEL	50917	Independent/Furnace		I	0:00	9:39	9:39	APPROVED PTW
749	132 KV Eminabad	JAHAN ZEB STEEL MILLS	50915	Independent/Furnace		I	0:00	23:30	23:30	APPROVED PTW
750	132 KV Eminabad	RIZWAN STEEL	50918	Independent/Furnace		I	0:00	10:19	10:19	APPROVED PTW
751	132 KV Eminabad	NEW HAFIZ STEEL	50921	Independent/Furnace		I	0:00	14:14	14:14	APPROVED PTW
752	132 KV Eminabad	KHAWJA STEEL	50913	Independent/Furnace		I	0:00	No-Load	#VALUE!	APPROVED PTW
753	132 KV Eminabad	BISMILLAH STEEL	50928	Independent/Furnace		I	0:00	13:21	13:21	NO-NOMINAL LOAD
754	132 KV Eminabad	IBRAHIM STEEL MILL	50914	Independent/Furnace		I	0:00	16:43	16:43	APPROVED PTW
755	132 KV Eminabad	IJAZ FURNACE	50919	Independent/Furnace		I	0:00	8:00	8:00	APPROVED PTW
756	132 KV Eminabad	M.R STEEL	50923	Independent/Furnace		I	0:00	12:18	12:18	APPROVED PTW
757	132 KV Eminabad	AKRAM STEEL INDUSTRY	50927	Independent/Furnace		I	0:00	12:49	12:49	APPROVED PTW
758	132 KV Eminabad	AL-HAMAD STEEL FURNACE	50920	Independent/Furnace		I	0:00	13:32	13:32	NO-NOMINAL LOAD
759	132 KV Eminabad	PRIME STEEL	50922	Independent/Furnace		I	0:00	8:04	8:04	APPROVED PTW
760	132 KV Eminabad	AL MADINA STEEL MILLS	50916	Independent/Furnace		I	0:00	No-Load	#VALUE!	APPROVED PTW

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
761	132 KV Qila Didar Singh	GUJRAT STEEL MILL	16311	Independent/Furnace		I	0:00	6:08	6:08	NO-NOMINAL LOAD
762	132 KV Qila Didar Singh	YASIN STEEL	16314	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
763	132 KV Narowal	M.NAWAZ STEEL MILL	14213	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
764	132 KV Narowal	ABDUL HAMEED STEEL MILL	14214	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
765	132 KV Daska Industrial	SARDAR STEEL	60018	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
766	132 KV Daska Industrial	N A STEEL	60014	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
767	132 KV Daska Industrial	MM STEEL	60009	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
768	132 KV Daska Industrial	HAMID FOUNDRY	60021	Independent/Furnace		I	0:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
769	132 KV Daska Industrial	ISLAM STEEL	60017	Independent/Furnace		I	0:00	4:53	4:53	NO-NOMINAL LOAD
770	132 KV Daska Industrial	A D STEEL	60015	Independent/Furnace		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
771	132 KV Daska Industrial	NAWAZ STEEL	60016	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
772	132 KV Daska Industrial	ROYAL STEEL	60008	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
773	132 KV Daska Industrial	AL MADINA SURGICAL	60019	Independent/Furnace		I	0:00	10:51	10:51	NO-NOMINAL LOAD
774	132 KV Daska Industrial	SINDHO STEEL FURNANCE	60010	Independent/Furnace		I	0:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
775	132 KV Daska Industrial	JEEVAY MADINA	60023	Independent/Furnace		I	0:00	4:15	4:15	NO-NOMINAL LOAD
776	132 KV Daska Industrial	DASKA STEEL MILL	60012	Independent/Furnace		I	0:00	9:36	9:36	NO-NOMINAL LOAD
777	132 KV Daska Industrial	A.M.STEEL	60020	Independent/Furnace		I	0:00	1:46	1:46	NO-NOMINAL LOAD
778	132 KV Daska Industrial	SHAHBAZ STEEL MILL	60013	Independent/Furnace		I	0:00	1:44	1:44	NO-NOMINAL LOAD

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
779	132 KV Daska Industrial	AL-BASHIR STEEL	60024	Independent/Furnace		I	0:00	0:33	0:33	NO-NOMINAL LOAD
780	132 KV Daska City	YOUNIS SURGICAL	26315	Independent/Furnace		I	0:00	10:49	10:49	NO-NOMINAL LOAD
781	132 KV Daska City	JAMIL STEEL	26316	Independent/Furnace		I	0:00	2:18	2:18	NO-NOMINAL LOAD
782	132 KV Daska City	REFINE STEEL	26317	Independent/Furnace		I	0:00	5:16	5:16	NO-NOMINAL LOAD
783	132 KV Chianwali	HKS RE-ROLLING MILLS	108210	Independent/Furnace		I	0:00	2:08	2:08	NO-NOMINAL LOAD
784	132 KV Chianwali	S.K STEEL	108212	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
785	132 KV Chianwali	POWER STEEL FURNACE	108205	Independent/Furnace		I	0:00	0:00	0:00	RELIEF BY RCC
786	132 KV Chianwali	A.K.STEEL	108206	Independent/Furnace		I	0:00	1:04	1:04	NO-NOMINAL LOAD
787	132 KV Khialy GRW	ADIL STEEL	112206	Independent/Furnace		I	0:00	4:30	4:30	NO-NOMINAL LOAD
788	132 KV Jalal Pur Jattan	EXPRESS BARNALA AJK	6711	AJK 11 KV Feeders		VI	8:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
789	132 KV Bhimber	SAMANI-2 AJK	46711	AJK 11 KV Feeders		VI	8:00	5:35	2:25	DUE TO OVER LOADING OF 500KV NOKHAR.
790	132 KV Bhimber	R1 IFTKHR ABAD AJK	46703	AJK 11 KV Feeders		VI	6:00	6:14	0:14	DUE TO OVER LOADING OF 500KV NOKHAR.
791	132 KV Bhimber	R-3(SAMANI-I) AJK	46705	AJK 11 KV Feeders		VI	6:00	4:05	1:55	DUE TO OVER LOADING OF 500KV NOKHAR.
792	132 KV Bhimber	BARNALA AJK	46706	AJK 11 KV Feeders		VI	6:00	4:52	1:08	DUE TO OVER LOADING OF 500KV NOKHAR.
793	132 KV Bhimber	IND-1 AJK	46709	AJK 11 KV Feeders		VI	8:00	8:03	0:03	LOAD REDUCED
794	132 KV Bhimber	BHIMBER-2 AJK	46707	AJK 11 KV Feeders		VI	8:00	10:42	2:42	BREAK DOWN
795	132 KV Bhimber	IND-2 AJK	46710	AJK 11 KV Feeders		VI	8:00	4:58	3:02	DUE TO OVER LOADING OF 500KV NOKHAR.
796	132 KV Bhimber	BHIMBER-1	46702	AJK 11 KV Feeders		VI	6:00	3:55	2:05	DUE TO OVER LOADING OF 500KV NOKHAR.

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
797	132 KV Bhimber	SAMANI EXPRESS AJK	46713	AJK 11 KV Feeders		VI	8:00	5:53	2:07	DUE TO OVER LOADING OF 500KV NOKHAR.
798	132 KV Bhimber	R2 KHJ.T.MILL AJK	46704	AJK 11 KV Feeders		VI	4:00	2:34	1:26	DUE TO OVER LOADING OF 500KV NOKHAR.
799	132 KV Awan Sharif	BARNALA-1 AJK	108805	AJK 11 KV Feeders		VI	8:00	6:03	1:57	DUE TO OVER LOADING OF 500KV NOKHAR.
800	132 KV Awan Sharif	BARNALA-2 AJK	108807	AJK 11 KV Feeders		VI	6:00	3:58	2:02	DUE TO OVER LOADING OF 500KV NOKHAR.
801	132 KV Lahore Road GRW	EPZ-2	72518	Independent EPZ		I	0:00	0:00	0:00	RELIEF BY RCC
802	132 KV Lahore Road GRW	EPZ-1	72517	Independent EPZ		I	0:00	0:00	0:00	RELIEF BY RCC
803	132 KV Sambrial	EPZ-3	18710	Independent EPZ		I	0:00	0:00	0:00	RELIEF BY RCC
804	132 KV Cantt. GRW	MLRS	95418	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
805	132 KV Cantt. GRW	GUJRANWALA MEDICAL COLLEGE	95423	Exempted Feeders		I	0:00	9:41	9:41	NO-NOMINAL LOAD
806	132 KV Wazirabad	CARDIOLOGY	22219	Exempted Feeders		I	0:00	0:24	0:24	FORCE BY RCC
807	132 KV Kharian	CENTRAL COMMAND	10714	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
808	132 KV Aroop GRW	POWER HOUSE	97410	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
809	132 KV Aroop GRW	NMC	97403	Exempted Feeders		I	0:00	Comm. Issue	#VALUE!	MONITORING SYSTEM ERROR
810	132 KV Gujrat-II	GUJRAT UNIVERSITY	46913	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
811	132 KV Hafizabad	MUJAHID		Exempted Feeders		I	0:00	15:54	15:54	NO-NOMINAL LOAD
812	132 KV Hafizabad	AIR FORCE	5502	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
813	132 KV Narowal	DISTRICT JAIL	14218	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
814	132 KV New Head Marala	BARRAGE	32301	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC

Power Outage Report

16-Aug-18

SR NO.	Grid Station	Feeder Name	Code	CATEGORY	CITY NAME	PITC CATEGORY	PLANED HOURS	Total Outage	DIFF	REMARKS
								HH:MM		
815	132 KV Sambrial	SIALKOT AIR PORT	18711	Exempted Feeders		I	0:00	15:52	15:52	NO-NOMINAL LOAD
816	220 KV Sahawal Sialkot-220kV	NEW AIRPORT	81307	Exempted Feeders		I	0:00	0:00	0:00	RELIEF BY RCC
817	132 KV Hafiz Abad-II	DISTRICT JAIL (HAFIZABAD)	108609	Exempted Feeders		I	0:00	0:30	0:30	FORCE BY RCC
818	132 KV Shaheen Abad GRW	LOHIANWALA	5037	Others		I	0:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR
819	132 KV Theri Sansi	BAKER MANDI	21414	Others		I	0:00	0:00	0:00	RELIEF BY RCC
820	132 KV Hafizabad	KOT MUBARIK(RASU)	5509	Others		I	0:00	0:00	0:00	RELIEF BY RCC
821	132 KV Daska Industrial	USMAN STEEL FURNANCE	60011	Others		I	0:00	23:59	23:59	MONITORING SYSTEM ERROR
822	132 KV Sialkot City	SPARE	37528	Others		I	0:00	0:00	0:00	RELIEF BY RCC
823	132 KV Sialkot Cantt	AUXILIARY	999001	Others		I	0:00	No-Load	#VALUE!	MONITORING SYSTEM ERROR

ABSTRACT OF POWER OUTAGE REPORT DATED: 16-08-2018

SR#	Remarks	PITC Category wise Quantity					
		I	II	III	VI	VII	Total
1	APPROVED PTW	38	-	-	-	-	38
2	EMERGENT PTW	5	-	-	-	-	5
3	BREAK DOWN	36	4	-	1	-	41
4	LOAD REDUCED	2	-	-	1	-	3
5	NO LOAD/NOMINAL LOAD / LOAD REDUCED AT CONSUMER SIDE	44	-	-	-	-	44
6	AS PER SCHEDULE	-	-	-	-	-	0
7	COMMUNICATION ERROR	62	-	-	1	-	63
8	DUE TO OVER LOADING	435	3	1	10	-	449
9	FORCE BY RCC	14	-	-	-	-	14
10	RELIEF BY RCC	126	1	-	-	-	127
11	TRIPPED OFF DUE TO HEAVY RAIN & WIND STORM	-	-	-	-	-	0
12	TRIPPINGS	39	-	-	-	-	39
TOTAL		801	8	1	13	0	823